



**GREENHOUSE GAS EMISSIONS ASSOCIATED
WITH VARIOUS METHODS OF POWER
GENERATION IN ONTARIO**

October 2016

Prepared For: Ontario Power Generation Inc.
700 University Avenue
Toronto, Ontario
M5G 1Z5

DISCLAIMER

Intrinsic Corp. (hereafter referred to as Intrinsic) provided this report to Ontario Power Generation Inc. (OPG) solely for the purpose stated in the report. Intrinsic does not accept any responsibility for the use of this report for any purpose other than as specifically intended by OPG. Intrinsic does not have, and does not accept, any responsibility or duty of care whether based in negligence or otherwise, in relation to the use of this report in whole or in part by any third party. Any alternate use, including that by a third party, or any reliance on or decision made based on this report, are the sole responsibility of the alternative user or third party. Intrinsic does not accept responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

Intrinsic makes no representation, warranty or condition with respect to this report or the information contained herein other than that it has exercised reasonable skill, care and diligence in accordance with accepted practice and usual standards of thoroughness and competence for the profession of toxicology and environmental science to assess and evaluate information acquired during the preparation of this report. Any information or facts provided by others, and referred to or utilized in the preparation of this report, is believed to be accurate without any independent verification or confirmation by Intrinsic. This report is based upon and limited by circumstances and conditions stated herein, and upon information available at the time of the preparation of the report.

Intrinsic has reserved all rights in this report, unless specifically agreed to otherwise in writing with OPG.

GREENHOUSE GAS EMISSIONS ASSOCIATED WITH VARIOUS METHODS OF POWER GENERATION IN ONTARIO

EXECUTIVE SUMMARY

Intrinsic Corp. (Intrinsic) has been retained by Ontario Power Generation Inc. (OPG) to compare greenhouse gas (GHG) emissions associated with various methods of energy production in Ontario over the next 40 years. Along with technical and economic factors, environmental impacts are an important element to consider when establishing a system of mixed electricity generation. Utilizing both renewable and non-renewable resources with low-carbon impact that can provide a consistent and reliable supply of electricity will address Ontario's energy requirements while minimizing impacts to the environment.

The objective of the study was to provide an impartial, scientifically defensible evaluation of the GHG emissions associated with various types of energy production projected to be utilized in Ontario until 2055. This period represents the projected operating life span of the refurbished Darlington Nuclear Generating Station. The study focused exclusively on the estimated GHG emissions released to the Ontario environment as a result of the operations and maintenance of facilities producing electricity rather than a Lifecycle Assessment (LCA) that addresses all potential upstream and downstream activities. This approach is consistent with the emissions forecast provided by the Independent Electricity System Operator (IESO) as part of Ontario's Long-Term Energy Plan.

Numerous LCAs have characterized GHG emissions for various forms of energy production. For conventional facilities utilizing fossil fuels such as coal or natural gas, the majority of GHG emissions occur during the production of energy as fuel resources are consumed. For other methods of energy production, the mining and processing of resources, the production of equipment, or the construction of facilities may represent the most emission-intensive stages. The overall lifecycle GHG emissions for nuclear, wind and hydro are often found to be similar and slightly below those for solar, with emissions for each of these more than an order of magnitude lower than lifecycle emissions for natural gas (Figure E-1).




Figure E-1 Comparison of Lifecycle Emissions for Various Methods of Energy Production (Asthma Society of Canada and Bruce Power, 2014).

Utilizing literature-based values, provincial databases of self-reported GHG emissions, and energy production estimates, resource-specific GHG emission rates per unit of electricity generated (*i.e.*, gram of CO₂ equivalents per kilowatt hour (g CO₂e/kWh)) were estimated for nuclear, wind, natural gas, solar PV, and hydroelectric energy production in Ontario (Table E-1).

Table E-1 Estimated Resource-Specific GHG Emission Rates for the Operation and Maintenance Stage	
Resource	GHG Emissions per Energy Production (g CO₂e/kWh)
Hydroelectric	0
Nuclear	0.15
Wind	0.74
Solar	6.15
Natural Gas	525

Resource-specific GHG emission rates were then used to estimate the total amount of GHGs emitted to meet Ontario’s energy requirements for three (3) distinct scenarios:

1. Current energy production, with nuclear representing approximately 60% of Ontario’s energy requirements, until 2024 during a period of staggered refurbishments to the Darlington and Bruce Generating Stations.
2. Projected future scenario after 2024 with a reduction in nuclear capacity following the scheduled closure of the Pickering Nuclear Generating Station and the completed refurbishment of the Darlington Nuclear Generating Station. Under this scenario it was assumed that the necessary capacity lost with the closure of the Pickering Station would be replaced by a combination of renewable sources (*i.e.*, hydro, wind and solar PV) and natural gas.
3. Alternate projected future scenario after 2024 in the absence of the Darlington refurbishment resulting in a reduction in nuclear capacity associated with the closure of both the Pickering and Darlington Stations. Under this scenario it was assumed that the

necessary capacity lost with the closure of the Pickering and Darlington Stations would be replaced by a combination of renewable sources (*i.e.*, hydro, wind and solar PV) and natural gas.

The loss of nuclear capacity with the closure of the Pickering Station after 2024 (Scenario 2), and the combined losses of capacity with the closure of both the Pickering and Darlington Stations in an alternate future scenario (Scenario 3), result in an increase in total GHG emissions to 16 and 26 MT CO₂e in 2025, respectively, relative to the total GHG emissions of 12 MT CO₂e in 2024 prior to the closure of these facilities and 7.2 MT CO₂e under the current 2016 scenario (Figure E-1). Fluctuations in emissions in Scenarios 2 and 3 are largely attributed to planned refurbishments to the Bruce Station occurring until 2031. The total reduction in GHG emissions from 2024 to 2055 associated with the continued use of the Darlington Station following refurbishment is estimated to be 297 MT CO₂e, with an average reduction of 9.6 MT CO₂e per year. This is equivalent to removing approximately 2,000,000 cars from Ontario’s roads per year. A reduction of 9.6 MT CO₂e per year also contributes to Ontario’s GHG emissions reduction targets under Ontario’s Climate Change Mitigation and Low-Carbon Economy Act, 2016, which calls for reductions from 1990 emissions levels (181.8 MT CO₂e) of 15% in 2020, 37% in 2030, and 80% in 2050 (MOECC, 2016), representing reductions of 27, 67 and 145 MT CO₂e, respectively.




Figure E-1 Projected Greenhouse Gas Emissions associated with Power Generation in Ontario (2016 to 2055)

The emissions profile is driven almost exclusively by energy production from natural gas facilities for each of the three (3) scenarios. Although the contribution of natural gas to the total energy production ranges from 9 to 32%, it consistently represents the largest source of GHGs

since the combustion of natural gas is the most emission-intensive operational process of each of the energy-producing resources. These significant increases in annual GHG emissions are anticipated even though an optimal scenario was assumed in which renewable resources such as wind, solar PV and hydro were able to increase their contribution to meet energy demands beyond the forecasted increase in production. Despite this assumption, a large portion of the capacity lost with the closure of the Darlington Station under Scenario 3 was assumed to be replaced by energy generated by natural gas facilities. Natural gas facilities were assumed to provide approximately 75% (or 20 TWh) of the total capacity lost under Scenario 3 from the closure of the Darlington Station in 2025 until 2036. It was assumed that if the Darlington Station refurbishments were not approved, a 20-year planning, approvals and construction phase would allow for a 10% increase (4.2 TWh) in energy production from hydroelectric facilities beginning in 2036. A subsequent 1% increase in hydroelectric capacity was assumed for every year after 2036. The technical feasibility of the assumed increased capacity for energy production for each resource was not evaluated as part of the current study.

Given that nuclear represents a large source of energy production in Ontario and the operational stage produces a low rate of GHG emissions, the loss of energy-generating capacity due to the closure of nuclear facilities would result in a significant increase in annual GHG emissions in order for Ontario to meet its future energy requirements.

GREENHOUSE GAS EMISSIONS ASSOCIATED WITH VARIOUS METHODS OF POWER GENERATION IN ONTARIO

Table of Contents

	Page
1.0 INTRODUCTION	1
1.1 Background	1
1.2 Study Scope and Objectives.....	4
2.0 METHODOLOGY	5
2.1 Systematic Search of the Literature.....	7
3.0 SCENARIO-SPECIFIC OUTPUT AND EMISSIONS	8
3.1 Nuclear.....	8
3.1.1 Estimated GHG Emission Rates	8
3.1.2 Assumptions, Limitations and Uncertainties	10
3.2 Wind.....	11
3.2.1 Estimated GHG Emission Rates	11
3.2.2 Assumptions, Limitations and Uncertainties	12
3.3 Natural Gas	13
3.3.1 Estimated GHG Emission Rates	15
3.3.2 Assumptions, Limitations and Uncertainties	16
3.4 Solar Photovoltaic	16
3.4.1 Estimated GHG Emission Rates	16
3.4.2 Assumptions, Limitations and Uncertainties	17
3.5 Hydroelectric	17
3.5.1 Estimated GHG Emission Rates	18
3.5.2 Assumptions, Limitations and Uncertainties	19
4.0 GHG EMISSIONS FORECAST FOR ONTARIO’S ENERGY PRODUCTION.....	20
5.0 OVERALL ASSUMPTIONS, LIMITATIONS AND UNCERTAINTIES.....	26
5.1 Exclusion of LCA Emissions.....	26
5.1.1 Nuclear	27
5.1.2 Wind	28
5.1.3 Natural Gas.....	28
5.1.4 Solar Photovoltaic.....	28
5.1.5 Hydroelectric.....	28
6.0 CONCLUSIONS	30
7.0 REFERENCES	31

List of Tables

Table E-1	Estimated Resource-Specific GHG Emission Rates for the Operation and Maintenance Stage	ii
Table 3-1	Energy Generation and GHG Emission Rates associated with Operation and Maintenance of Nuclear Facilities in Ontario	9
Table 3-2	GHG Emissions Rates associated with Operation and Maintenance of Wind Facilities in Ontario.....	12
Table 3-3	Natural Gas Generating Stations in Ontario ^a	13
Table 3-4	Energy Generation and GHG Emission Rates associated with Operation and Maintenance of Natural Gas Facilities in Ontario.....	15
Table 3-5	GHG Emission Rates associated with Operation and Maintenance of Solar PV in Ontario	17
Table 4-1	Estimated Resource-Specific GHG Emission Rates for the Operation and Maintenance Stage	20
Table 4-2	Projected Power Generation in Ontario by Resource: 2016 to 2055 (TWh). Error! Bookmark not defined.	
Table 4-3	Projected Greenhouse Gas Emissions Associated with Power Generation in Ontario: 2016 to 2055 (MT CO ₂ e)..... Error! Bookmark not defined.	

List of Figures

Figure E-1	Projected Greenhouse Gas Emissions associated with Power Generation in Ontario (2016 to 2055)	iii
Figure 1-1	Actual Energy Production in 2014 (IESO, 2015) Compared to Forecast Energy Production in 2032 (OPA, 2014).....	2
Figure 1-2	Comparison of Lifecycle Emissions for Various Methods of Energy Production (Asthma Society of Canada and Bruce Power, 2014).....	3
Figure 2-1	Projected Power Generation in Ontario (2016 to 2055).	6
Figure 4-1	Projected Greenhouse Gas Emissions associated with Power Generation in Ontario (2016 to 2055)	21
Figure 4-2	Projected Power Generation in Ontario by Resource (2016 to 2055)	23

Appendices

APPENDIX A	Literature Search Strategy
-------------------	----------------------------

1.0 INTRODUCTION

Intrinsic Corp. (Intrinsic) has been retained by Ontario Power Generation Inc. (OPG) to compare greenhouse gas (GHG) emissions associated with various methods of energy production in Ontario over the next 40 years. Along with technical and economic factors, environmental impacts are an important element to consider when establishing a system of mixed electricity generation. Utilizing both renewable and non-renewable resources with low-carbon impact that can provide a consistent and reliable supply of electricity will address Ontario's energy requirements while minimizing impacts to the environment.

A literature and database search was conducted to characterize GHG emission rates associated with regular operating activities for various methods of power generation utilized in Ontario, specifically nuclear, wind, solar photovoltaic (PV), hydro, and natural gas. This information was used to estimate total GHG emissions associated with Ontario's energy requirements under current and potential future scenarios. This study focuses exclusively on GHG emissions released in Ontario as a result of the operational stages of energy production.

1.1 Background

The province of Ontario's Long-Term Energy Plan (LTEP) was released in 2013 (MOE, 2013). This report detailed the proposed plan to meet Ontario's forecasted energy demands up to the year 2032, as well the predicted GHG emissions associated with the production of this energy. As part of the province's GHG emissions reduction program, Ontario has adopted measures to reduce GHG emissions associated with the electricity sector. This included the phasing-out of coal-fired electricity generation as of April 2014 largely through increasing generation from nuclear units and adding new natural gas-fired generating facilities, and the implementation of the Feed-in-Tariff (FIT) program under the Green Energy Act which guarantees long-term rates for electricity generated using renewable resources such as wind and solar. These efforts have contributed to the steady decline in GHG emissions from the electricity sector since 2008. The Ontario Ministry of Environment and Climate Change (MOECC) reported that these declines were expected to continue for the next few years followed by an increase in emissions associated with a growing Ontario population, a recovering economy, and a reduction in energy production from nuclear units during a period of refurbishment resulting in an increased reliance on natural gas-fired plants (MOECC, 2013).

Currently, Ontario's energy demands are met through a mix of renewable and non-renewable resources, with nuclear representing approximately 60% of production followed by hydro (24%), natural gas/oil (10%), wind (6%), bioenergy (0.3%), solar (0.2%) and other minor contributors, as reported for actual energy production in 2015 (IESO, 2016a). In 2032, while nuclear continues to provide Ontario's base load (44%), a reduced capacity in energy production from nuclear will shift energy demands to a greater dependence on natural gas and renewable resources (Figure 1-1).




Figure 1-1 Actual Energy Production in 2015 (IESO, 2016a) Compared to Forecast Energy Production in 2032 (OPA, 2014)

While energy conservation is anticipated to significantly contribute to Ontario's energy efficiency, representing approximately 16% of the forecast energy demand for 2032 (MOE, 2013), achieving continued reductions in GHG emissions while meeting an overall increase in energy requirements will be dependent on the ability of clean resources to meet the majority of the energy demand.

GHG emissions are an important factor to consider when evaluating advantages and disadvantages of various energy producing options as it represents the contribution of these processes to global warming and climate change. Facilities in Canada report GHG emissions as carbon dioxide equivalents (CO₂e), which is calculated by applying a global warming potential (GWP) (UNEP, 2010) to emissions for CO₂ (GWP =1), methane (CH₄) (GWP= 21) and nitrous oxide (N₂O) (GWP=310). For the current study, the unit of measurement for GHG

emissions is the emission rate per unit of electricity generated (*i.e.*, gram of CO₂ equivalents per kilowatt hour (g CO₂e/kWh)).

The estimation of GHG emissions for various methods of energy production often involves the use of life cycle assessments (LCAs) that consider energy requirements and emissions associated with all aspects of an energy generating facility or system, including construction, operation (energy production) and decommissioning (Figure 1-2). For conventional facilities utilizing fossil fuels such as coal or natural gas, the majority of GHG emissions occur during the production of energy as fuel resources are consumed. For other methods of energy production, the mining and processing of resources, the production of equipment, or the construction of facilities may represent the most emission-intensive stages. Although nuclear and renewable resources such as wind, solar and hydro are often regarded as emission-free energy sources because GHGs are not directly emitted during the electricity generating stages, standard operating and maintenance activities require energy inputs, many of which may involve the use of fossil fuels (Lenzen, 2008).




Figure 1-2 Comparison of Lifecycle Emissions for Various Methods of Energy Production (Asthma Society of Canada and Bruce Power, 2014).

Numerous studies have been conducted to characterize GHG emissions associated with various forms of energy production. These have included LCAs as well as critical reviews and meta-analyses of pooled data extracted from individual studies. While many have derived information from international resources, others have focused specifically on the generation of electricity within Canada, as well as within Ontario alone. To derive GHG emission rates associated with the operational stage of energy production in Ontario, the current study utilized information from several of these studies including Mallia and Lewis (2013), Hatch (2014), CERI (2008), Andseta *et al.* (1998), Lenzen (2008), Sovacool (2008), Warner and Heath (2012), Fthenakis and Kim (2007), and Nugent and Sovacool (2014). Information provided within these resources was either used directly to represent emission estimates, or indirectly to provide

context surrounding the use of facility-specific GHG emission rates reported to Federal or Provincial databases for energy-generating facilities in Ontario.

1.2 Study Scope and Objectives

The objective of the study was to provide an impartial, scientifically defensible evaluation of the GHG emissions associated with various types of energy production projected to be utilized in Ontario over the next 40 years. This period represents the projected operating life span of the refurbished Darlington Nuclear Generating Station. The study focused exclusively on the estimated GHG emissions released to the Ontario environment as a result of the operations and maintenance of facilities producing electricity to meet the province's energy requirements rather than an LCA that addresses all potential upstream and downstream activities. This approach is consistent with the emissions forecast provided by the MOECC and the Independent Electricity System Operator (IESO) as part of the LTEP.

A literature and database search was conducted to characterize GHG emissions associated with regular operating activities for various methods of power generation utilized in Ontario, specifically nuclear, wind, solar PV, hydro, and natural gas. This information was used to estimate total GHG emissions associated with Ontario's energy requirements under three distinct scenarios:

1. Current energy production, with nuclear representing approximately 60% of Ontario's energy requirements, until 2024 during a period of staggered refurbishments to the Darlington and Bruce Generating Stations.
2. Projected future scenario after 2024 with a reduction in nuclear capacity following the scheduled closure of the Pickering Nuclear Generating Station and the completed refurbishment of the Darlington Nuclear Generating Station. Under this scenario it was assumed that the necessary capacity lost with the closure of the Pickering Station would be replaced by a combination of renewable sources (*i.e.*, hydro, wind and solar) and natural gas.
3. Alternate projected future scenario after 2024 in the absence of the Darlington refurbishment resulting in a reduction in nuclear capacity associated with the closure of both the Pickering and Darlington Stations. Under this scenario it was assumed that the necessary capacity lost with the closure of the Pickering and Darlington Stations would be replaced by a combination of renewable sources (*i.e.*, hydro, wind and solar) and natural gas.

Although GHG emissions from each resource (*i.e.*, nuclear, wind, solar PV, hydro and natural gas) were considered independently, the overall evaluation considered the total GHG emissions produced by all resources in order to meet Ontario's energy requirements under each of the three scenarios listed above. The technical feasibility of the assumed increased capacity for energy production for each resource was not evaluated as part of the current study.

2.0 METHODOLOGY

To provide an accurate assessment of GHG emissions for electricity generating facilities in Ontario, priority was given to annual emissions data reported under the Greenhouse Gas Emissions Regulation (Regulation 452/09) available at: <https://www.ontario.ca/data/greenhouse-gas-emissions-reporting-facility>. Introduced in 2009, Regulation 452/09 requires all large GHG emitters to report their annual emissions. For electricity generation, the threshold requirement for reporting is 25,000 tonnes CO₂e/year. For those facilities or energy generating methods with emissions that are below the reporting threshold, alternate resources were utilized to estimate GHG emissions. This included GHG emissions data provided by OPG for the Darlington and Pickering nuclear stations. GHG emissions data retrieved from the Regulation 452/09 database or provided by OPG was paired with the corresponding sector-specific electricity generation data provided by IESO (<http://www.ieso.ca/Pages/Power-Data/Supply.aspx>) to establish the emission rate on a g CO₂e/kWh basis.

In addition to the utilization of Ontario-specific GHG emissions data, a review was conducted of the most recent white and grey literature (literature that is not commercially published) as it relates to the GHG emissions during regular operating activities for each source of power generation (*i.e.*, nuclear, wind, solar PV, hydro and natural gas) considered in this study. Although facility-specific emission rates were considered for some resources, a single emission rate for each resource was derived for use in the GHG emission scenarios.

The objective of the literature search and review was to identify the most accurate and relevant resources to characterize GHG emissions in Ontario and to describe any uncertainties associated with this information. The literature review was used to fill data gaps in the Ontario GHG emissions database, as well as to ground-truth the database and provide a description of the operations and maintenance activities that may have resulted in the reported emissions. Resources considered in the current study are those that clearly described the methodology for calculating GHG emissions, were publicly available, and are reflective of current technologies and practices.

Following the estimation of emission rates for each energy resource, rates were applied to the IESO/Ontario Power Authority (OPA) energy generation forecasts (Table 2-1) to describe the GHG emissions for the years 2015 to 2024 for Scenario 1, as described above.

Table 2-1 Ontario's Energy Production Forecast (IESO/OPA)							
Year	Energy Production (TWh)						
	Nuclear	Hydro	Natural Gas/Imports	Wind	Solar PV	Bioenergy	Total
2016	84.6	39.9	13.6	12	3	2	154.8
2017	79.7	40.4	14.5	13	4	2	153.5
2018	79.7	40.6	16.4	13	4	3	156.4
2019	75.7	40.8	18.5	14	4	3	156.2
2020	74.2	40.8	18.7	15	5	3	156.9
2021	55.3	40.9	31.2	17	5	4	153.4
2022	56.1	41.8	31.2	17	5	4	155.6
2023	56	42.1	31.7	17	5	4	156
2024	58.9	42.2	30.1	17	5	4	157.5

Table 2-1 Ontario's Energy Production Forecast (IESO/OPA)							
Year	Energy Production (TWh)						
	Nuclear	Hydro	Natural Gas/Imports	Wind	Solar PV	Bioenergy	Total
2025	60.9	42.2	29.7	17	5	4	158.8
2026	65.3	42.2	27.2	17	5	4	160.6
2027	62.3	42.3	30.2	17	5	4	160.7
2028	65.9	42.4	28.5	17	5	4	163
2029	64.4	42.3	30.9	17	5	4	163.6
2030	69.2	42.3	29.9	17	5	4	167.4
2031	71.3	42.2	29.8	17	4	4	169.3
2032	74.7	42.1	29.2	17	4	4	171.6

Resource-specific emission rates were applied to the energy forecasts for 2025 to 2055 following an adjustment to account for an assumed reduction in nuclear capacity following the closure of the Pickering Station, as described for Scenario 2, and a further reduction in nuclear capacity following the closure of both the Pickering and Darlington Stations, as described for Scenario 3. Given that the LTEP only provides an energy production forecast to 2032, a linear regression was established to predict energy production to 2055 (*i.e.*, the end of the 40-year period) (Figure 2-1). The linear regression is an extrapolation of anticipated future requirements based on the IESO forecast from 2016 to 2032.




Figure 2-1 Projected Power Generation in Ontario (2016 to 2055).

2.1 Systematic Search of the Literature

A systematic and comprehensive search of the published literature was conducted to identify, as best possible, all white (peer-reviewed published literature) and grey literature (literature available elsewhere) related to GHG emissions associated with power generation operations in the Ontario context. The literature search was performed in a step-wise manner using three search strategies:

- On-line electronic databases
- Citation sourcing
- Professional experience

A description of the search strategy is provided in Appendix A.

3.0 SCENARIO-SPECIFIC OUTPUT AND EMISSIONS

3.1 Nuclear

In Ontario, nuclear power is produced using Canada Deuterium Uranium (CANDU) Reactors which use unenriched uranium as fuel and deuterium oxide (or heavy water) as a coolant and moderator. There are currently 18 CANDU reactors operating in 3 facilities in Ontario including: 8 at the Bruce Power Generating Station, 6 in the OPG Pickering Generating Station, and 4 in the OPG Darlington Generating Station. The combined installed capacity for these reactors for 2016 is 11,295 MW, with a projected decrease in capacity to 9,852 MW by 2032. The reduced capacity is associated with the scheduled closure of the Pickering Station in 2024; however, staggered refurbishments to both the Darlington and Bruce Stations will maintain capacity from each of these facilities.

3.1.1 *Estimated GHG Emission Rates*

While the generation of electricity from nuclear resources does not directly emit GHGs, emissions occur during various stages of the overall lifecycle. An LCA for Ontario nuclear power plants found that GHG emissions from the Ontario facilities were on the low end of the range reported in the literature for nuclear energy production facilities, likely because the energy-intensive uranium enrichment process is not required for CANDU reactors (Mallia and Lewis, 2013).

The nuclear power lifecycle generally consists of five (5) stages: 1) the front-end consisting of the mining, milling, conversion and enrichment of uranium; 2) the construction of the facility including generators, turbines, and cooling towers; 3) the operation phase in which electricity is produced and energy is required for facility maintenance and fuels for backup generators; 4) the back-end consisting of fuel processing, interim storage and final disposal and management of nuclear waste; and 5) the decommissioning and dismantling of the facility and the reclamation of the mine sites (Sovacool, 2008). The current study focused exclusively on the GHG emissions associated with the operations phase. This restricted the number of applicable studies from which to derive GHG emissions since many LCAs simplified the phases into three aggregate categories (upstream, operation, and downstream), combining uranium mining, milling conversion, enrichment, fuel rod fabrication, transportation, mine rehabilitation with standard operations for the operations phase. Operational processes often were not subdivided into facility operations and processes related to uranium mining and processing since GHG emissions related to facility operations were typically negligible or aggregated with other processes (Warner and Heath, 2012).

As reported by OPG, GHG emissions associated with energy production at the Pickering and Darlington Stations are associated with the burning of diesel fuel for standby generator (SG) and emergency power generator (EPG) testing. Emissions are calculated based on annual fuel deliveries which vary annually. GHG emissions from 2015 were notably higher for the Pickering Station due to extended testing of the SGs and EPGs (Table 3-1). Based on data from 2011 to 2015, the five-year average GHG emissions for the Pickering and Darlington Stations were 7,501 and 3,050 tonnes CO₂e, respectively. Emissions generated by the Pickering and

Darlington Stations did not exceed the Reg. 452/09 reporting threshold; therefore, emissions data was only available from OPG directly.

GHG emissions from the Bruce Station historically exceeded the Reg. 452/09 reporting threshold, and as a result, annual emissions are available on the Ontario database. GHG emissions from the Bruce Station have steadily declined since it first started reporting emissions in 2010 under Reg. 452/09 due to the Bruce Steam Plant shut-down strategy, resulting in the reduction in emissions from 68,464 tonnes CO₂e in 2010 to 3,681 tonnes CO₂e in 2014. GHG emissions from 2014 (3,681 tonnes CO₂e) fall within the 5-year averages for Pickering and Darlington (7,501 and 3,050 tonnes CO₂e).

Annual energy production for the Pickering and Darlington Stations were provided by OPG and were used to calculate 5-year average emission rates. Given that energy production from the Bruce Station was not reported, it was calculated as the difference of the total energy produced by nuclear facilities as reported by IESO (<http://www.ieso.ca/Pages/Power-Data/Supply.aspx>) and the energy produced by the Pickering and Darlington Stations as reported by OPG. Due to the significant reductions in emissions reported for the Bruce Station following plant improvements, emission rates were based on data for 2014 as they are considered to be representative of current and future conditions. For 2014, IESO reported that nuclear facilities provided 94,900 GWh to the Ontario grid. Using the production data for the Pickering (20,045 GWh) and Darlington (27,960 GWh) Stations, the estimated production for the Bruce Station was 46,895 GWh.

Table 3-1 Energy Generation and GHG Emission Rates associated with Operation and Maintenance of Nuclear Facilities in Ontario			
Facility	GHG Emissions (tonnes CO₂e)	Electricity Generation (GWh)	Emissions per Energy Production (g CO₂e/kWh)
Pickering^a			
2011	5,657	19,675	0.29
2012	9,300	20,735	0.45
2013	4,279	19,642	0.22
2014	4,351	20,045	0.22
2015	13,919	21,231	0.66
Average	7,501	20,266	0.37
Darlington^a			
2011	4,007	28,951	0.14
2012	1,525	28,318	0.054
2013	1,224	25,051	0.049
2014	4,806	27,960	0.17
2015	3,688	23,293	0.16
Average	3,050	26,715	0.11
Bruce^b			
2010	68,464	-	-
2011	46,489	-	-
2012	32,311	-	-
2013	16,215	-	-
2014	3,681	46,895 ^c	0.078

- Emissions per unit of energy were not considered for these years since they are not considered to be representative of current or future conditions.

^a Emission and energy generation data for the Pickering and Darlington Stations was provided by OPG.

^b Emission data for the Bruce Station was taken from the Regulation 452/09 database <https://www.ontario.ca/data/greenhouse-gas-emissions-reporting-facility>

Table 3-1 Energy Generation and GHG Emission Rates associated with Operation and Maintenance of Nuclear Facilities in Ontario

<i>Facility</i>	<i>GHG Emissions (tonnes CO₂e)</i>	<i>Electricity Generation (GWh)</i>	<i>Emissions per Energy Production (g CO₂e/kWh)</i>
-----------------	---	-------------------------------------	--

^c Represents the difference in total energy production from all nuclear facilities for 2014 (94,900 GWh) as reported by IESO and the energy production reported by OPG for the Pickering and Darlington Stations.

A single emission rate for nuclear energy production was derived by weighting emission rates for the individual Stations by their contribution to total nuclear energy production in 2014 (49.4% Bruce; 29.5% Darlington; and 21.1% Pickering) (*i.e.*, $(0.494 \times 0.078 \text{ g CO}_2\text{e/kWh}) + (0.295 \times 0.11 \text{ g CO}_2\text{e/kWh}) + (0.211 \times 0.37 \text{ g CO}_2\text{e/kWh}) = 0.15 \text{ g CO}_2\text{e/kWh}$). This estimate is consistent with the calculated operational emission rate of 0.2 g CO₂e/kWh reported in an LCA by Mallia and Lewis (2013) for the same nuclear facilities based on data from 2008, as well as a rate of 0.11 g CO₂e/kWh reported by CERI (2008) based on data from 2005 to 2006 for Ontario facilities.

Although most LCAs have either grouped operation and maintenance with additional life cycle processes, or have not detailed the factors considered in the estimation of emissions associated with standard operation, others have utilized a similar approach as presented above by utilizing fuel usage. Emissions associated with plant operations were estimated based on fuel used for start-up of auxiliary steam generators and in-plant heating from studies conducted in 1970s, 80s and 90s. Fuel usages ranged from 0.1 to 3 million gal/year producing a range in GHG emission rates of 0.1 to 6 g CO₂e/kWh (Fthenakis and Kim, 2007). Emission estimates based on fuel usage for the Pickering and Darlington Stations fall within the low end of this range.

Therefore, the estimated GHG emission rate of 0.15 g CO₂e/kWh for the operational component of nuclear facilities in Ontario was selected for use in the current study.

3.1.2 Assumptions, Limitations and Uncertainties

Although the mining, milling and refining of uranium is included within the operation stage of some LCAs, the current study did not include GHGs associated with the extraction and processing of fuels or materials for any of the power generating methods to allow for a consistent comparison across each resource.

Some LCAs have reported that the energy-intensive production of heavy water as a coolant and moderator would result in significant emissions for CANDU reactors. The current study does not include emissions associated with the production of heavy water, but rather assumes that production is carbon neutral as it was generated utilizing nuclear-generated steam rather than relying on fossil fuels as a heat source and upgrading occurs at each station.

A critical survey of LCAs for various types of nuclear generators worldwide reported that 17% of the total lifecycle GHG emissions were attributed to operations. This represents an emission rate of 11.58 g CO₂e/kWh and is associated with the energy required for maintenance, cooling and fuel cycles, backup generators, and during outages and shutdowns. Of the nineteen (19) studies included in the Sovacool (2008) survey, one (Andseta *et al.*, 1998) was specific to CANDU reactors in Canada. Although Sovacool (2008) reported an emission rate of 11.9 g

CO₂e/kWh associated with operations from Andseta *et al.* (1998), this was based on the historical production of heavy water utilizing fossil fuel energy sources for this process rather than the most recent production and upgrading of heavy water utilizing steam which has negligible emissions. This is consistent with Mallia and Lewis (2013) which found that operational emissions (0.2 g CO₂e/kWh) for nuclear plants in Ontario only represented approximately 4% of the total LCA emissions.

3.2 Wind

Wind power development in Ontario has increased significantly over the past decade. Under Ontario's LTEP, this trend is expected to continue, with the contribution of wind power to the province's energy production anticipated to increase from 3% in 2013 to 9% in 2032 (MOE, 2013). Currently, there are 16 commercial wind farms and individual wind operators that provide approximately 2,853 MW in nameplate capacity (*i.e.*, the maximum output rating). By the end of 2018, a number of wind power projects currently under development are scheduled to be in service, which will provide an additional 2,862 MW in nameplate capacity (IESO, 2016b). It is important to recognize that nameplate capacity is not representative of actual power generation. According to the Ontario Wind Integration Study (GE Energy, 2006), the capacity factor of wind power, which is the average power output during all hours over a year divided by the nameplate capacity, is approximately 20% in Ontario.

3.2.1 Estimated GHG Emission Rates

While the generation of electricity from wind turbines does not directly emit GHGs, emissions occur during various stages of the overall lifecycle. The wind power life cycle generally consists of four (4) stages: 1) fabrication of the wind turbine consisting of mining, processing materials, and manufacturing; 2) construction of the wind turbine consisting of transporting turbine components, constructing foundation and substations, and assembling support structure and wind turbine; 3) operation and maintenance of the wind turbine; and 4) decommissioning activities consisting of deconstruction of the wind turbine, disposal, recycling of turbine components, and land reclamation, as required (Nugent and Sovacool, 2014). An LCA for Ontario wind farms found that GHG emissions were on the low end of the range reported in the literature, partly due to the exclusive use of onshore turbines rather than the energy- and material-intensive construction of offshore wind farms (Mallia and Lewis, 2013). The current assessment focused exclusively on the GHG emissions associated with the operation and maintenance phase of onshore wind turbines.

The operation and maintenance phase of on-shore wind turbines generally has the lowest GHG contribution to the overall lifecycle (Noori *et al.*, 2015; Nugent and Sovacool, 2014 Raadal *et al.*, 2011; Thomson and Harrison, 2015). While there are no direct GHG emissions associated with wind power generation, there are periodic maintenance activities that are required to ensure continued operation which may indirectly contribute GHG emissions (Nugent and Sovacool, 2014; Crawford, 2009; Hatch, 2014), including:

- regular maintenance and cleaning;
- component replacement over the service life of the wind turbine; and,

- change of oils and lubricants.

A literature search was completed to identify the GHG emissions associated with operation and maintenance of wind facilities within North America. Wind turbines of all nameplate capacities are located both on- and off-shore around the world. Since Ontario only has onshore 1.5 – 2.3 MW wind turbines in commercial operation, studies discussing wind turbines with similar specifications were targeted; however, due to the limited multiple resources reporting GHG emission estimates for the operation and maintenance phase, additional studies were considered. As part of an LCA literature review for power generation in Canada, Hatch (2014) derived an operational emission rate of 0.49 g CO₂e/kWh. This value was based on activities associated with the periodic maintenance of onshore wind farms in Canada including wind turbines with a capacity of greater than 100 kW. A similar value of 0.74 g CO₂e/kWh was reported by Mallia and Lewis (2013) based on the LCA conducted for Ontario energy production. The relevant GHG emission rates identified for wind is presented in Table 3-2.

Nugent and Sovacool (2014) conducted a meta-survey of lifecycle studies on GHG emissions associated with wind power. Twelve (12) studies were identified that presented GHG emissions for the operational phase of wind power. These studies provided a range from 0.02 to 83.6 g CO₂e/kWh, with mean and standard deviation values of 14.36 ± 26.3 g CO₂e/kWh. Many of the identified studies were not considered to be relevant to the Ontario context either due to: (1) the very low or very high nameplate capacity of the wind turbines; or, (2) study based on off-shore wind turbines. Three (3) of the studies identified were considered relevant and were also included in Table 3-2.

Table 3-2 GHG Emissions Rates associated with Operation and Maintenance of Wind Facilities in Ontario

<i>Reference</i>	<i>GHG Emissions per Energy Production (g CO₂e/kWh)</i>	<i>Percentage of Total LCA Emissions</i>
Chen et al. (2011) ^a	0.02	3.5%
Hatch (2014)	0.49	4%
Mallia and Lewis (2013)	0.74	7%
Martinez et al. (2009) ^a	0.35	5.3%
Oebels and Pacca (2013) ^a	0.04	0.6%
Thomson and Harrison (2015)	0.90	6%

^a As cited in Nugent and Savacool (2014)

Based on the information presented in Table 3-2, the operation and maintenance phase is estimated to contribute a small percentage of the overall LCA emissions, ranging from 0.6 to 7%. The GHG emissions per energy production value of 0.74 g CO₂e/kWh calculated by Mallia and Lewis (2013) was selected for use in the current assessment. This value was derived based on a LCA conducted for Ontario energy production and is most representative of GHG emissions in Ontario. This value is generally consistent with values provided in other studies.

3.2.2 Assumptions, Limitations and Uncertainties

While the operation and maintenance phase of the wind power life cycle generally has the lowest GHG emissions, there is some variability in GHG emission estimates, ranging from 6% (Thomson and Harrison, 2015) to 24% (Nugent and Sovacool, 2014). Some sources of

variability in estimating GHG emissions per energy production associated with operation and maintenance of wind facilities include wind speed and maintenance assumptions. The average wind speed plays an important role in determining the GHG emissions per energy production. As a result, the same wind turbine placed in two different locations may produce differing amounts of electricity (Davidsson et al., 2012; Crawford, 2009).

The assumptions regarding the maintenance requirements over the course of a wind turbine's lifetime can significantly alter the GHG emissions per energy production. Currently, there does not appear to be a consistent set of assumptions used in LCAs of wind power facilities. As noted by Arvesen and Hertwich (2012), some LCAs do not consider the replacement of parts in their assessment, while others assume a certain proportion of components will need to be replaced.

3.3 Natural Gas

Natural gas power generation provides flexibility to address fluctuations in electricity supply and demand. It is often regarded as a practical source of energy to support the intermittency of energy generated by renewable resources such as wind and solar. Under the LTEP, the contribution of natural gas to the province's energy production was 10% in 2013 and is projected to remain at 10% in 2032 (MOE, 2013). Currently, there are 39 natural gas-fueled generating stations in Ontario that provide approximately 8,900 MW of total capacity (Table 3-3). Four (4) projects are currently under development and are anticipated to provide an additional 1,200 MW of capacity to the Ontario power grid (IESO, 2016c).

Unlike resources such as nuclear, wind, solar and hydro where the majority of GHG emissions are related to the upstream and downstream stages of the life cycle, the combustion of natural gas during the operational stage of energy production represents the greatest source of GHGs. The majority of the natural gas facilities in Ontario utilize combined cycle gas turbines, which incorporates steam generation technologies with the natural gas combustion turbines to improve overall efficiency. The York Energy Centre is the only facility in Ontario that utilizes simple cycle gas turbines, which generates power by creating superheated gas to drive the gas turbines. Twenty-three (23) of Ontario's natural gas stations are cogeneration/combined heat and power (CHP) plants that provide both electricity to the power grid and steam/heat for industrial use.

Table 3-3 Natural Gas Generating Stations in Ontario^a				
<i>Facility</i>	<i>Location</i>	<i>Type</i>	<i>Nameplate Capacity (MW)</i>	<i>GHG Emissions (tonnes CO₂e)^b</i>
Current Facilities				
Algoma Energy Co-Gen	Sault Ste. Marie	CHP	63	1,331,298
Atlantic Power Kapuskasing	Kapuskasing	Combined Cycle	40	128,971
Atlantic Power Nipigon Project	Nipigon	Combined Cycle	40	102,099
Atlantic Power North Bay	North Bay	Combined Cycle	40	130,117
Atlantic Power Tunis Project	Iroquois Falls	Combined Cycle	43	121,032
Birchmount Energy Centre	Markham	CHP	2.6	-
Brighton Beach Power Station	Windsor	Combined Cycle	541.3	128,442
Bur Oak Energy Centre	Markham	CHP	3.25	-
Cardinal Power Gas Cogeneration	Cardinal	Combined Cycle, Cogeneration	156	462,634

Table 3-3 Natural Gas Generating Stations in Ontario^a

<i>Facility</i>	<i>Location</i>	<i>Type</i>	<i>Nameplate Capacity (MW)</i>	<i>GHG Emissions (tonnes CO₂e)^b</i>
Durham College District Energy	Oshawa	CHP	2.3	-
East Windsor Cogeneration Centre	Windsor	CHP	84	85,932
Goreway Power Station	Brampton	Combined Cycle	839.1	862,040
Great Northern Tri-Gen Facility	Kingsville	CHP	11.3	-
Greenfield Energy Centre	Sarnia	Combined Cycle	1005	988,648
GTAA Cogeneration Plant	Mississauga	Combined Cycle, Cogeneration	90	312,491
Halton Hills Generating Station	Halton Hills	Combined Cycle	641.5	592,862
Lake Superior Cogeneration Plant	Lake Superior	Cogeneration	110	205,735
Lennox Generating Station	Napanee	Natural Gas/Oil	2000	125,226
London Cogeneration Facility	London	CHP	12	39,788
Maitland Site Generation Station	Maitland	Cogeneration	50	163,463
Northland Cochrane Generating Station	Cochrane	Cogeneration	42	247,055
Northland Iroquois Falls	Iroquois Falls	Combined Cycle	120	330,573
Northland Kingston Generating Station	Kingston	Combined Cycle	110	328,112
Northland Kirkland Lake	Kirkland Lake	Combined cycle	85	496,902
Northland Thorold Cogeneration Project	Thorold	CHP	287	311,117
Portlands Energy Centre	Toronto	Combined Cycle	550	415,212
St. Clair Energy Centre	Sarnia	Combined Cycle	577	360,494
Sudbury District Energy Cogeneration Plant	Sudbury	Cogeneration	5	-
Sudbury District Energy Hospital Cogeneration Plant	Sudbury	Cogeneration	6.7	-
Transalta Douglas (Mississauga) Facility	Mississauga	Cogeneration	108	1,041,160
Transalta Ottawa Health Science Center CGS	Ottawa	Combined Cycle, Cogeneration	73.7	146,310
Transalta Sarnia Regional Cogeneration Plant	Sarnia	Cogeneration	506	173,390
Transalta Windsor Facility	Windsor	Cogeneration	72	-
Trent Valley Cogeneration Plant	Trenton	Cogeneration	6.7	-
Villa Colombo Vaughan	Kleinburg	CHP	0.2	-
Warden Energy Centre	Markham	CHP	5.0	375,004
West Windsor Generating Facility	Windsor	Combined Cycle	136	179,775
Whitby Cogeneration Project	Whitby	Cogeneration	50	51,175
York Energy Centre	Township of King	Simple Cycle	393	1,331,298
Facilities Under Development				
Green Electron Power Project	St. Clair Township	Combined Cycle	289	-
Hanlon Creek District Energy Project	Guelph	CHP	10.2	-
Napanee Generating Station	Napanee	Combined Cycle	900	-
Rosa Flora Growers	Niagara	CHP	4.0	-

CHP – combined heat and power

^a Source: IESO (2016c).

^b Average GHG emissions between 2010 and 2014 with 87% electricity allocation factor, as appropriate.

- GHG emission data was not provided by IESO (2016c).

3.3.1 Estimated GHG Emission Rates

The natural gas power lifecycle generally consists of four (4) stages: 1) the front-end consisting of the extraction and production of natural gas, including both conventional and unconventional sources (e.g., shale gas); 2) the construction of the facility including turbines and generators; 3) the operation phase in which electricity is produced through the combustion of natural gas; and 4) the decommissioning, dismantling and disposal of all facility components.

Despite the existence of numerous literature-based GHG emission estimates for natural gas facilities, it is anticipated that the most accurate method for estimating emission rates specific to the Ontario scenario is through the utilization of facility-specific emission rates reported under Reg. 452/09 combined with the total annual power generation reported by IESO (2016a) for natural gas facilities (Table 3-4). GHG emissions data was not reported for the 9 natural gas facilities with GHG emissions less than the Reg. 452/09 reporting limit; however, due to the low nameplate capacity of these facilities (*i.e.*, less than 11.3 MW capacity), exclusion of this data was not considered to significantly influence the estimated GHG emission rate for the natural gas resource.

For cogeneration and CHP facilities, the GHG emissions are associated with the generation of both electricity and thermal energy (*i.e.*, steam). Mallia and Lewis (2013) derived an electricity allocation ratio of 87% based on energy output capacity data for two cogeneration facilities in Ontario which would result in a 13% reduction in the overall GHG emission rate per unit energy production. In an effort to only consider GHG emissions associated with electricity generation, an allocation factor of 87%, as derived by Mallia and Lewis (2013), was applied to the total GHG emissions for cogeneration and CHP facilities in Ontario.

<i>Year</i>	<i>GHG (tonnes CO_{2e})^a</i>	<i>Generation (GWh)^b</i>	<i>Emissions per Energy Production (g CO_{2e}/kWh)</i>
2010	10,440,055	20,500	509
2011	11,135,590	22,000	506
2012	11,564,718	22,200	521
2013	9,798,724	18,200	538
2014	8,143,841	14,800	550
Average	10,216,585	19,500	525

^a Emission data was taken from the Regulation 452/09 database <https://www.ontario.ca/data/greenhouse-gas-emissions-reporting-facility> and represents the total reported GHG emissions for all natural gas facilities in Ontario.

^b Total energy production for natural gas facilities were taken from IESO (2016a).

Based on data from 2010 to 2014, the average annual GHG emissions per energy production for natural gas was 525 g CO_{2e}/kWh. This estimate is generally consistent with the average emission rate of 435 g CO_{2e}/kWh reported in an LCA by Mallia and Lewis (2013) for natural gas facilities in Ontario based on data from 2008, and averages of 390 g CO_{2e}/kWh and 445 g CO_{2e}/kWh reported by Hatch (2014) and CERI (2008), respectively, for facilities across Canada.

Therefore, the estimated GHG emission rate of 525 g CO_{2e}/kWh for the operational component of natural gas facilities in Ontario was selected for use in the current study.

3.3.2 Assumptions, Limitations and Uncertainties

Given that a number of the natural gas facilities in Ontario are cogeneration or CHP, GHG emission rates per unit energy production would most accurately be estimated by allocating a portion of the GHG emissions reported for these facilities to the beneficial co-production of thermal energy utilized for other applications. As noted above, Mallia and Lewis (2013) derived an electricity allocation ratio of 87% based on energy output capacity data for two cogeneration facilities in Ontario which would result in a 13% reduction in the overall GHG emission rate per unit energy production. For the current study, insufficient facility-specific information was available to derive a similar allocation ratio. As such, there is the potential for some uncertainty in the derivation of the overall GHG emission rate; however, based on a comparison of the selected GHG emission rate to values presented by Mallia and Lewis (2013), Hatch (2014), and CERI (2008), the selected GHG emission rate is generally consistent with other investigations.

To be consistent with the estimation of GHG emission rates for nuclear and other power generation methods, GHGs associated with the mining, extraction and transportation of fuels and materials was not included in the current study.

3.4 Solar Photovoltaic

Solar PV currently plays a minor role in Ontario's power generation. Under the LTEP, the contribution of solar PV to the province's energy production is expected to double from 1% in 2013 to 2% in 2032 (MOE, 2013). Currently, solar PV facilities in Ontario provide 1,235 MW in nameplate capacity. By the end of 2017, a number of solar PV projects under development are scheduled to be in service, which will provide an additional 939 MW in nameplate capacity (IESO, 2016d).

3.4.1 Estimated GHG Emission Rates

While the generation of electricity from solar PV does not directly emit GHGs, emissions occur during various stages of the overall lifecycle. The solar PV power cycle generally consists of four (4) stages: 1) fabrication of the solar PV modules consisting of mining, smelting, refining, and purification; 2) fabrication of the balance of systems including inverters, transformers, wiring, and structural support; 3) operation and maintenance of the solar PV; and 4) decommissioning activities (Fthenakis and Kim, 2007). The current study focused exclusively on the GHG emissions associated with the operation and maintenance phase.

A review of GHG emissions from solar PV reported a range in lifetime emissions of 28 to 110 g CO₂e/kWh for crystalline silicon and 18 to 48 g CO₂e/kWh for cadmium telluride (CdTe) (Environment Canada, 2012). The fabrication and installation of the solar PV have the highest GHG contribution to the overall lifecycle, while the operation/maintenance phase of solar PV have a small contribution (Environment Canada, 2012; Hsu *et al.*, 2012). There are no direct GHG emissions associated with solar PV power generation; however, operation and maintenance activities can indirectly result in GHG emissions, such as maintaining ground vegetation, preventative maintenance, and washing of panels (Hsu *et al.*, 2012; Turney and Fthenakis, 2011).

Nugent and Sovacool (2014) conducted a meta-survey of lifecycle studies on GHG emissions associated with solar PV. Only two (2) studies were identified to present GHG emissions for the operational phase of solar PV. These studies provided a range of 0 to 12.3 g CO₂e/kWh (Table 3-5).

<i>Reference</i>	<i>GHG Emissions per Energy Production (g CO₂e/kWh)</i>	<i>Percentage of Total LCA Emissions</i>
Jungbluth (2005)	0	0%
Hondo (2005)	6.0-12.3 ^a	23.1%

^a A range in operational GHG emissions was presented for current technologies as well as future cases. In each case, operational emissions represented 23.1% of the total emissions.

Nugent and Sovacool (2014) utilized the limited available information to derive an emission rate of 6.15 g CO₂e/kWh based on the mean of the reported values of 0 g CO₂e/kWh reported in Jungbluth (2005) and the upper end of the range of 12.3 g CO₂e/kWh reported by Hondo (2005). Given the lack of other literature-based values, the GHG emission rate of 6.15 g CO₂e/kWh was selected for use in the current study.

3.4.2 Assumptions, Limitations and Uncertainties

While the operation and maintenance phase of the solar PV life cycle is reported to have the lowest GHG emissions, there is variability in the few estimates available in the literature, which range from 0% to 23% (Nugent and Sovacool, 2014). There are limited details provided in the original studies that describe the methods and assumptions used to derive the operational-phase emission rates; therefore, an assessment of the relevance of each of the available estimates to solar PV in Ontario could not be conducted. Use of the mean of the available estimates may result in a notable over- or underestimation of GHG emissions associated with this stage in the Ontario context.

When estimating GHG emissions per unit energy production, the amount of energy generated by the solar PV units will significantly affect the calculated rates. There are two (2) main factors that can impact energy production and the resulting GHG emission rate for solar PV: insolation and efficiency. Insolation (or solar irradiance) represents the amount of solar radiation energy that reaches a given surface during a specific time. Insolation varies greatly around the world and even across Ontario and impacts the overall electricity generation capacity of solar PV, and in turn, the lifecycle GHG emissions rate for a solar facility (Nugent and Sovacool, 2014). Another consideration is the efficiency of the solar PV technology. The efficiency of commercially available solar PV varies greatly from 7% to 18% (Environment Canada, 2012). As a result, studies evaluating solar PV facilities in different parts of the world that utilize different types of solar PV technology may derive vastly different GHG emission rates.

3.5 Hydroelectric

Under the LTEP, the contribution of hydro to the province's energy production was 22% in 2013 and is projected to remain at 22% through to 2032 (MOE, 2013). Hydro has a nameplate capacity of approximately 10,000 MW, contributing 40 TWh to Ontario's electricity grid in 2014.

Hydroelectric facilities in Ontario include both reservoir systems as well as numerous run-of-river stations. Due to the capacity of reservoirs to store water, these stations generally have a larger electricity generating capacity than run-of-river stations (Mallia and Lewis, 2013). Unlike wind and solar, hydro represents a non-intermittent source of renewable energy.

3.5.1 Estimated GHG Emission Rates

GHG emissions from hydroelectric stations in Ontario did not exceed the Reg. 452/09 reporting thresholds; therefore, the estimation of an emission rate was based on literature-derived values. GHG emissions over the life cycle of hydroelectric facilities are primarily associated with three (3) stages: 1) the front-end consisting of the construction of the facility; 2) the decomposition of organic material as lands are flooded for reservoirs; and 3) the decommissioning of the facility and the release of GHGs associated with the remaining biomass (Mallia and Lewis, 2013). One of the most significant sources of GHGs is the release of carbon dioxide and methane as biomass such as plants, trees and soils undergo decomposition in the creation of reservoirs. GHGs created by the decomposition organic materials diffuse through the water column within the reservoir and are subsequently released to the atmosphere (Steinhurst *et al.*, 2012). Emission rates are largely dependent on the type of habitat flooded, the size and depth of the reservoir, and the climate (Gagnon and van de Vate, 1997; Steinhurst *et al.*, 2012). The flooding of Boreal forests in colder climates, such as those found in Ontario, is reported to result in lower emissions than found for tropical areas, with an average GHG emission rate of 15 g CO₂e/kWh (Mallia and Lewis, 2013; Gagnon and van de Vate, 1997). This is consistent with an estimated range of 0.35 to 30 g CO₂e/kWh reported for European hydroelectric facilities (Weisser, 2007).

The decomposition of biomass represents a potentially far more significant source of GHG emissions than the estimated rate of 1 to 10 g CO₂e/kWh for the construction of the dam and related equipment (Gagnon and van de Vate, 1997). The decommissioning of these facilities is estimated to result in an even greater source of emissions due to the release of methane from exposed sediments following the draining of the reservoir (Pacca, 2007). GHG emissions associated with the decomposition of biomass are not a concern for run-of-river facilities which do not require the flooding of large areas for reservoirs (Mallia and Lewis, 2013).

GHG emissions associated with the decomposition of biomass are reported to be temporary, with some estimating a peak in emissions approximately 2 to 5 years following impoundment, followed by a gradual decline in emissions which may reach those found in natural lakes after more than 10 years (Hydro Quebec, 2016). During the periods of peak emissions following flooding, GHG emissions may be similar to those associated with gas-fired facilities, decreasing from a rate of 671 g CO₂e/kWh in the first year following flooding to 238 g CO₂e/kWh following the fourth year (Steinhurst *et al.*, 2012).

To be consistent with the derivation of GHG emission estimates for other resources, the flooding of reservoirs and the associated emissions associated with the decomposition of biomass was considered to be a component of the construction phase and was not included within the operational stage for the current study. When GHG emissions related to biomass degradation

are excluded, emissions during the operational phase of hydroelectricity generation are considered to be negligible (Amor *et al.*, 2011). Unlike other resources, hydro facilities do not necessarily rely on fossil fuels or outside sources of energy to resume energy production following an outage (Steinhurst *et al.*, 2012).

Therefore, the estimated GHG emission rate for the operational component of hydroelectric facilities in Ontario was assumed to be negligible in the current study.

3.5.2 Assumptions, Limitations and Uncertainties

The largest source of GHG emissions for hydroelectric facilities is reported to be related to the decomposition of biomass, primarily within the first few years of flooding and following decommissioning when accumulated sediments are exposed. There is a significant degree of variability in GHG emissions associated with decomposition, with rates affected by temperature, depth of water, and the type of land flooded to create the reservoir. The rate at which GHG emissions decrease from the initial peak in emissions following flooding is generally unknown. Emissions associated with the decomposition of biomass are generally included within the construction phase of an LCA and therefore, were not included in the operational GHG emission estimates in order to be consistent with the derivation of emission rates for other resources. Failure to account for GHG emissions associated with decomposition, as well as the reduction in the GHG-reducing capacity related to the loss of terrestrial ecological community, may result in a notable underestimation of GHG emissions for the production of energy by hydroelectric facilities.

4.0 GHG EMISSIONS FORECAST FOR ONTARIO'S ENERGY PRODUCTION

Utilizing literature-based values, provincial databases of self-reported GHG emissions, and energy production estimates, resource-specific GHG emission rates were estimated for nuclear, wind, natural gas, solar PV, and hydroelectric energy production in Ontario (Table 4-1).

Table 4-1 Estimated Resource-Specific GHG Emission Rates for the Operation and Maintenance Stage	
Resource	GHG Emissions per Energy Production (g CO_{2e}/kWh)
Hydroelectric	0
Nuclear	0.15
Wind	0.74
Solar	6.15
Natural Gas	525

Resource-specific GHG emission rates were then used to estimate the total amount of GHGs emitted to meet Ontario's energy requirements for three (3) distinct scenarios:

1. Current energy production, with nuclear representing approximately 60% of Ontario's energy requirements, until 2024 during a period of staggered refurbishments to the Darlington and Bruce Generating Stations.
2. Projected future scenario after 2024 with a reduction in nuclear capacity following the scheduled closure of the Pickering Nuclear Generating Station and the completed refurbishment of the Darlington Nuclear Generating Station. Under this scenario it was assumed that the necessary capacity lost with the closure of the Pickering Station would be replaced by a combination of renewable sources (*i.e.*, hydro, wind and solar) and natural gas.
3. Alternate projected future scenario after 2024 in the absence of the Darlington refurbishment resulting in a reduction in nuclear capacity associated with the closure of both the Pickering and Darlington Stations. Under this scenario it was assumed that the necessary capacity lost with the closure of the Pickering and Darlington Stations would be replaced by a combination of renewable sources (*i.e.*, hydro, wind and solar) and natural gas.

The ratio of the contribution of each resource to the total energy demand under Scenario 2 following the reduction in nuclear capacity was assumed to remain consistent with forecast ratios reported by IESO from 2016 to 2032. This accounted for the fact that the anticipated increased capacity of each resource is not equal, with the capacities of some resources expected to increase at different rates during specific time periods. As a result, no one single resource will replace the loss in nuclear capacity, or contribute to a degree that is inconsistent with the electricity mix presented by IESO. It was also assumed that importation of energy from outside of the province would not be sufficient to replace the lost capacity. Significant increases to energy production in neighbouring provinces would be required, as well as the construction of additional transmission lines to facilitate the delivery of energy to the Ontario grid.

Energy production forecasts provided in the 2013 LTEP were based on the planning assumption that the Pickering Station would cease energy production in 2020. In January 2016, it was

announced that OPG plans to pursue continued operation until 2024. All six operating units would operate until 2022, at which point two units would cease operations and the remaining four units would operate until 2024. Therefore, the emissions forecasts for Scenarios 2 and 3 assume a decrease in energy production from the Pickering Station of approximately 1/3 for 2023 and 2024.


The loss of nuclear capacity with the closure of the Pickering Station after 2024 (Scenario 2), and the combined losses of capacity with the closure of both the Pickering and Darlington Stations in an alternate future scenario (Scenario 3), result in an increase in total GHG emissions to 16 and 26 MT CO₂e in 2025, respectively, relative to the total GHG emissions of 12 MT CO₂e in 2024 prior to the closure of these facilities and 7.2 MT CO₂e under the current 2016 scenario (Figure 4-1; Table 4-2). Fluctuations in emissions in Scenarios 2 and 3 are largely attributed to planned refurbishments to the Bruce Station occurring until 2031. The total reduction in GHG emissions from 2024 to 2055 associated with the continued use of the Darlington Station following refurbishment is estimated to be 297 MT CO₂e, with an average reduction of 9.6 MT CO₂e per year. This is equivalent to removing approximately 2,000,000 cars from Ontario's roads per year assuming an annual average GHG emission rate of 4,700 kg CO₂e per vehicle (U.S. EPA, 2016). A reduction of 9.6 MT CO₂e per year also contributes to Ontario's GHG emissions reduction targets under Ontario's Climate Change Mitigation and Low-Carbon Economy Act, 2016, which calls for reductions from 1990 emissions levels (181.8 MT CO₂e) of 15% in 2020, 37% in 2030, and 80% in 2050 (MOECC, 2016), representing reductions of 27, 67 and 145 MT CO₂e, respectively.



Figure 4-1 Projected Greenhouse Gas Emissions associated with Power Generation in Ontario (2016 to 2055)

The emissions profile is driven almost exclusively by energy production from natural gas facilities for each of the three (3) scenarios. Although the contribution of natural gas to the total

energy production ranges from 9 to 32%, it consistently represents the largest source of GHGs since the combustion of natural gas is the most emission-intensive operational process of each of the energy-producing resources. These significant increases in annual GHG emissions are anticipated even though an optimal scenario was assumed in which renewable resources such as wind, solar PV and hydro were able to increase their contribution to meet energy demands beyond the forecasted increase in production (Figure 4-2; Table 4-3). Despite this assumption, a large portion of the capacity lost with the closure of the Darlington Station under Scenario 3 was assumed to be replaced by energy generated by natural gas facilities. Natural gas facilities were assumed to provide approximately 75% (or 20 TWh) of the total capacity lost under Scenario 3 from the closure of the Darlington Station in 2025 until 2036. It was assumed that if the Darlington Station refurbishments were not approved, a 20-year planning, approvals and construction phase would allow for a 10% increase (4.2 TWh) in energy production from hydroelectric facilities beginning in 2036. A subsequent 1% increase in hydroelectric capacity was assumed for every year after 2036. The technical feasibility of the assumed increased capacity for energy production for each resource was not evaluated as part of the current study. The technical feasibility of the assumed increased capacity for energy production for each resource was not evaluated as part of the current study.






Figure 4-2 Projected Power Generation in Ontario by Resource (2016 to 2055)

Given that nuclear represents a large source of energy production in Ontario and the operational stage produces a low rate of GHG emissions, the loss of energy-generating capacity due to the closure of nuclear facilities would result in a significant increase in annual GHG emissions in order for Ontario to meet its future energy requirements.

Table 4-2 Projected Power Generation in Ontario by Resource: 2016 to 2055 (TWh)

Year	Nuclear		Hydroelectric		Natural Gas		Wind		Solar PV		Bioenergy		Total
	Sc. 2	Sc. 3	Sc. 2	Sc. 3	Sc. 2	Sc. 3	Sc. 2	Sc. 3	Sc. 2	Sc. 3	Sc. 2	Sc. 3	
2016	85	85	40	40	14	14	12	12	3.0	3.0	2.0	2.0	154.8
2017	80	80	40	40	15	15	13	13	4.0	4.0	2.0	2.0	153.5
2018	80	80	41	41	16	16	13	13	4.0	4.0	3.0	3.0	156.4
2019	76	76	41	41	19	19	14	14	4.0	4.0	3.0	3.0	156.2
2020	74	74	41	41	19	19	15	15	5.0	5.0	3.0	3.0	156.9
2021	74	74	41	41	16	16	15	15	5.0	5.0	3.0	3.0	153.4
2022	74	74	41	41	18	18	15	15	5.0	5.0	3.0	3.0	155.6
2023	67	67	41	41	22	22	17	17	5.8	5.8	3.0	3.0	156.0
2024	67	67	41	41	22	22	18	18	6.0	6.0	3.0	3.0	157.5
2025	61	34	42	42	30	50	17	22	5.0	6.4	4.0	4.0	158.8
2026	65	39	42	42	27	47	17	22	5.0	6.5	4.0	4.0	160.6
2027	62	36	42	42	30	51	17	22	5.0	6.4	4.0	4.0	160.7
2028	66	39	42	42	29	49	17	22	5.0	6.4	4.0	4.0	163.0
2029	64	38	42	42	31	51	17	22	5.0	6.4	4.0	4.0	163.6
2030	69	42	42	42	30	50	17	22	5.0	6.4	4.0	4.0	167.4
2031	71	45	43	42	30	51	17	22	4.0	5.2	4.0	4.0	169.3
2032	75	48	42	42	29	50	17	22	4.0	5.2	4.0	4.0	171.6
2033	75	48	41	42	28	48	17	22	3.9	5.1	3.9	3.9	168.7
2034	75	48	42	42	29	49	17	22	3.9	5.1	4.0	4.0	169.7
2035	75	48	42	42	29	50	17	22	4.0	5.2	4.0	4.0	170.7
2036	75	48	42	46	29	46	17	22	4.0	5.2	4.0	4.0	171.7
2037	75	48	43	47	30	47	17	22	4.1	5.2	4.0	4.0	172.7
2038	75	48	43	47	30	47	17	22	4.1	5.2	4.0	4.0	173.7
2039	75	48	44	48	30	47	18	22	4.2	5.3	4.1	4.1	174.7
2040	75	48	44	48	31	48	18	23	4.2	5.3	4.1	4.1	175.7
2041	75	48	45	49	31	48	18	23	4.2	5.3	4.1	4.1	176.7
2042	75	48	45	49	31	48	18	23	4.3	5.4	4.1	4.1	177.7
2043	75	48	46	50	32	49	18	23	4.3	5.4	4.2	4.2	178.7
2044	75	48	46	50	32	49	19	23	4.4	5.4	4.2	4.2	179.7
2045	75	48	46	51	32	49	19	23	4.4	5.5	4.2	4.2	180.7
2046	75	48	47	51	33	50	19	23	4.5	5.5	4.2	4.2	181.7
2047	75	48	47	52	33	50	19	23	4.5	5.5	4.3	4.3	182.7
2048	75	48	48	52	33	50	19	24	4.5	5.5	4.3	4.3	183.7
2049	75	48	48	53	33	51	19	24	4.6	5.6	4.3	4.3	184.7
2050	75	48	49	53	34	51	20	24	4.6	5.6	4.3	4.3	185.7
2051	75	48	49	54	34	51	20	24	4.7	5.6	4.4	4.4	186.7
2052	75	48	49	54	34	51	20	24	4.7	5.7	4.4	4.4	187.7
2053	75	48	50	55	35	52	20	24	4.8	5.7	4.4	4.4	188.7
2054	75	48	50	55	35	52	20	24	4.8	5.7	4.4	4.4	189.7
2055	75	48	51	56	35	52	21	24	4.8	5.8	4.4	4.4	190.7

Table 4-3 Projected Greenhouse Gas Emissions Associated with Power Generation in Ontario: 2016 to 2055 (MT CO₂e)

Year	Nuclear		Hydroelectric		Natural Gas		Wind		Solar PV		Total	
	Sc. 2	Sc. 3	Sc. 2	Sc. 3	Sc. 2	Sc. 3	Sc. 2	Sc. 3	Sc. 2	Sc. 3	Sc. 2	Sc. 3
2016	0.013	0.013	0	0	7.1	7.1	0.0089	0.0089	0.018	0.018	7.2	7.2
2017	0.012	0.012	0	0	7.6	7.6	0.010	0.010	0.025	0.025	7.7	7.7
2018	0.012	0.012	0	0	8.6	8.6	0.010	0.010	0.025	0.025	8.7	8.7
2019	0.011	0.011	0	0	9.7	9.7	0.010	0.010	0.025	0.025	9.8	9.8
2020	0.011	0.011	0	0	9.8	9.8	0.011	0.011	0.031	0.031	9.9	9.9
2021	0.011	0.011	0	0	8.1	8.1	0.011	0.011	0.031	0.031	8.2	8.2
2022	0.011	0.011	0	0	9.2	9.2	0.011	0.011	0.031	0.031	9.2	9.2
2023	0.010	0.010	0	0	11	11	0.013	0.013	0.036	0.036	11	11
2024	0.010	0.010	0	0	12	12	0.013	0.013	0.037	0.037	12	12
2025	0.0091	0.0051	0	0	16	26	0.013	0.016	0.031	0.040	16	26
2026	0.010	0.0058	0	0	14	25	0.013	0.016	0.031	0.040	14	25
2027	0.0093	0.0053	0	0	16	27	0.013	0.016	0.031	0.039	16	27
2028	0.010	0.0059	0	0	15	26	0.013	0.016	0.031	0.040	15	26
2029	0.010	0.0057	0	0	16	27	0.013	0.016	0.031	0.039	16	27
2030	0.010	0.0064	0	0	16	26	0.013	0.016	0.031	0.039	16	27
2031	0.011	0.0067	0	0	16	27	0.013	0.016	0.025	0.032	16	27
2032	0.011	0.0072	0	0	15	26	0.013	0.016	0.025	0.032	15	26
2033	0.011	0.0072	0	0	15	25	0.012	0.016	0.024	0.031	15	25
2034	0.011	0.0072	0	0	15	26	0.012	0.016	0.024	0.032	15	26
2035	0.011	0.0072	0	0	15	26	0.013	0.016	0.025	0.032	15	26
2036	0.011	0.0072	0	0	15	24	0.013	0.016	0.025	0.032	16	24
2037	0.011	0.0072	0	0	16	24	0.013	0.016	0.025	0.032	16	25
2038	0.011	0.0072	0	0	16	25	0.013	0.017	0.025	0.032	16	25
2039	0.011	0.0072	0	0	16	25	0.013	0.017	0.026	0.032	16	25
2040	0.011	0.0072	0	0	16	25	0.013	0.017	0.026	0.033	16	25
2041	0.011	0.0072	0	0	16	25	0.013	0.017	0.026	0.033	16	25
2042	0.011	0.0072	0	0	16	25	0.013	0.017	0.026	0.033	16	25
2043	0.011	0.0072	0	0	17	26	0.014	0.017	0.027	0.033	17	26
2044	0.011	0.0072	0	0	17	26	0.014	0.017	0.027	0.033	17	26
2045	0.011	0.0072	0	0	17	26	0.014	0.017	0.027	0.034	17	26
2046	0.011	0.0072	0	0	17	26	0.014	0.017	0.027	0.034	17	26
2047	0.011	0.0072	0	0	17	26	0.014	0.017	0.028	0.034	17	26
2048	0.011	0.0072	0	0	17	26	0.014	0.017	0.028	0.034	17	26
2049	0.011	0.0072	0	0	18	27	0.014	0.018	0.028	0.034	18	27
2050	0.011	0.0072	0	0	18	27	0.015	0.018	0.028	0.034	18	27
2051	0.011	0.0072	0	0	18	27	0.015	0.018	0.029	0.035	18	27
2052	0.011	0.0072	0	0	18	27	0.015	0.018	0.029	0.035	18	27
2053	0.011	0.0072	0	0	18	27	0.015	0.018	0.029	0.035	18	27
2054	0.011	0.0072	0	0	18	27	0.015	0.018	0.029	0.035	18	27
2055	0.011	0.0072	0	0	19	27	0.015	0.018	0.030	0.035	19	27

5.0 OVERALL ASSUMPTIONS, LIMITATIONS AND UNCERTAINTIES

The current study focused exclusively on the GHGs emitted in Ontario during the operational stage of energy production in Ontario. It must be noted that while this may provide a description of the GHGs emitted on an annual basis, it does not represent the total GHGs emitted over the lifetime of an energy-producing resource/facility, or additional considerations related to the disposal of waste materials generated during the production of energy. For some resources, GHG emissions during the operational stage are negligible relative to the emissions associated with the upstream and downstream stages, including resource extraction, facility construction, decommissioning and land reclamation. Emissions related to each of these stages are often amortized over the lifetime of the energy-producing facility within an LCA to estimate a lifetime annual GHG emission rate. This is achieved through complex evaluations of all aspects of a facility's lifetime within an LCA. A brief discussion of lifetime emission estimates for each resource is provided in Section 5.1.

Along with the assumptions, limitations and uncertainties listed within each of the individual sections describing the estimation of GHG emission rates in Section 3, numerous additional assumptions were employed in the derivation of emission estimates and the emission forecasts under each of the Scenarios, including:

- The current study considered GHG emissions associated with the generation of electricity rather than the final delivery of electricity to the end user. Therefore, the estimated emission rates per unit of energy do not account for electricity losses occurring during transmission and distribution;
- Emissions related to imported electricity, bioenergy or other resources were not considered. This will have resulted in the underestimation of total GHG emissions to the Ontario environment. However, given that bioenergy and other resources do not significantly contribute to the total energy production, this omission is not considered to significantly affect the overall emissions forecast;
- It was assumed that each resource (*i.e.*, natural gas, wind, solar PV and hydroelectric) will be able to increase their energy-producing capacity to levels that exceed those presented by IESO to contribute to total energy production needs following the loss of nuclear. An evaluation of the feasibility of each of these resources to meet the increased energy demands assumed under Scenarios 2 and 3 was not completed;
- The increased contribution of intermittent resources such as wind and solar to meet energy demand following the reduction of nuclear capacity in Scenarios 2 and 3 may inherently assume an increased capacity for energy storage in the future.

5.1 Exclusion of LCA Emissions

Full LCAs are often utilized when comparing the potential environmental impacts associated with the generation of electricity through multiple methods. This includes GHG emissions resulting from all life stages of the energy supply chain, beginning with the extraction of resources to fuel combustion or construct facilities, through to the decommissioning stage including waste management, land reclamation and the recycling of materials. Failure to

consider all stages of the lifecycle and focus exclusively on the emissions occurring during the operational phase may result in the omission of the majority of the lifetime emissions for some energy production methods, while capturing the most emission-intensive stage for others. The overall lifecycle GHG emissions for nuclear, wind and hydro are often found to be similar and slightly below those for solar, with emissions for each of these more than an order of magnitude lower than lifecycle emissions for natural gas (Table 5-1).

Table 5-1 Ranges of Full Lifecycle GHG Emission Rates for Various Methods of Power Generation^a	
Resource	GHG Emissions per Energy Production (g CO₂e/kWh)
Hydroelectric	10 - 22
Nuclear	4.8 - 66
Wind	10 - 34.1
Solar	32 – 49.9
Natural Gas	435 - 540

^a Values generally represent means from LCA literature reviews conducted by one or more of the following resources: Hatch (2014), Mallia and Lewis (2013), Sovacool (2008), Lenzen (2008), Andseta *et al.* (1998), Nugent and Sovacool (2014), and CERI (2008).

A brief description of the estimated contribution of the emissions associated with the operation and maintenance stage to the total lifetime emissions for each energy-producing method is described below.

5.1.1 Nuclear

A critical survey of LCAs for nuclear power reported a range in GHG emission rates over the lifetime of a plant of 1.4 to 288 g CO₂e/kWh, with a mean of 66 g CO₂e/kWh (Sovacool, 2008). This high degree of variability is consistent with several similar LCA reviews (Warner and Heath, 2012; Fthenakis and Kim, 2007; Lanzen, 2008). One of the greatest sources of variability in emission estimates was related to the quality of uranium ore which significantly affects the energy requirements for mining and milling, as well as mine land reclamation. The type of mining (*i.e.*, open-pit or underground), as well as explosives, solvents and techniques utilized within each type of mining, also had a notable effect on the variability of the estimates. Other factors that contributed significantly to the variability in emission estimates were the local energy source utilized for the mining of uranium, the type of uranium enrichment, the reactor type, site selection, the operational lifetime, and the LCA method (Sovacool, 2008). Total lifecycle GHG emissions for CANDU reactors were estimated to be 4.8 and 15 g CO₂e/kWh by Mallia and Lewis (2013) and Andseta *et al.* (1998), respectively. These estimates are notably lower than the means of 66 and 65 g CO₂e/kWh reported by Sovacool (2008) and Lanzen (2008), respectively.

Based on the best available information, it is estimated that exclusion of all components other than operation may result in the omission of 96% of the total lifecycle emissions associated with the production of energy by nuclear facilities in Ontario.

5.1.2 Wind

A critical survey of GHG emissions from wind power reported a range in emissions over the lifetime of a wind facility of 0.4 g to 364.8 g CO₂e/kWh, with a mean of 34.1 g CO₂e/kWh (Nugent and Sovacool, 2014). The majority of the GHG emissions associated with wind power are related to the fabrication and installation of the wind turbines, which has been estimated to contribute approximately 90 to 99% of the lifetime GHG emissions (Raadal *et al.*, 2011). Since many of these studies include the energy- and material-intensive construction of offshore wind farms which are not applicable within the Ontario context, the average LCA GHG emission estimate of 11 g CO₂e/kWh reported independently by both Mallia and Lewis (2013) and Hatch (2014) may be the most applicable. Given that GHG emissions associated with the operational stage was estimated to be 0.74 g CO₂e/kWh within Mallia and Lewis (2013) and 0.49 g CO₂e/kWh within Hatch (2014), it is estimated that exclusion of all components other than operation may result in the omission of approximately 93 to 96% of the total lifecycle emissions associated with the production of energy by wind farms in Ontario.

5.1.3 Natural Gas

The average total GHG emissions over the lifetime of a natural gas facility within Ontario was estimated to be 497 g CO₂e/kWh, with emissions from the operational phase estimated at 435 g CO₂e/kWh (or 87% of total emissions) (Mallia and Lewis, 2013). Hatch (2014) reported similar results, with emissions from the operational phase (390 g CO₂e/kWh) representing 82% of the total LCA emissions (478 g CO₂e/kWh), as did CERI (2008) with emissions from the operational phase (445 g CO₂e/kWh) also representing 82% of the total LCA emissions (540 g CO₂e/kWh). Therefore, it is estimated that exclusion of all components other than operation may result in the omission of approximately 12 to 18% of the total lifecycle emissions associated with the production of energy by natural gas facilities.

5.1.4 Solar Photovoltaic

A critical survey of GHG emissions from solar PV reported a range in emissions over the lifetime range from 17.5 to 110 g CO₂e/kWh, with a mean of 49.9 g CO₂e/kWh (Nugent and Sovacool, 2014). The majority of the GHG emissions associated with solar PV are related to the material extraction and fabrication phases (Environment Canada, 2012), which has been estimated to contribute approximately 71% of the lifetime GHG emissions (Nugent and Sovacool, 2014). Therefore, it is estimated that exclusion of all components other than operation may result in the omission of approximately 71% of the total lifecycle emissions associated with the production of energy by solar PV facilities in Ontario.

5.1.5 Hydroelectric

Mallia and Lewis (2013) estimated total life cycle GHG emission rates of 1.5 and 22.5 g CO₂e/kWh for run-of-river and reservoir hydroelectric facilities, respectively, in Ontario. While both included emission estimates for the construction and decommissioning stages, GHG emissions for the reservoir systems was significantly higher due to the decomposition of biomass occurring within flooded ecosystems. An overall weighted average of 22 g CO₂e/kWh

was derived for all hydroelectric energy production in Ontario. This estimate is at the low end of the range of 0.5 to 250 g CO₂e/kWh reported for run-of –river and reservoirs in boreal forests within the literature (Steinhurst *et al.*, 2012; Raadal *et al.*, 2011) and is consistent with an estimate of 15 g CO₂e/kWh reported for facilities in cold climates (Gagnon and van de Vate, 1997).

Given that the current study assumed that GHG emissions associated with the operational component of hydroelectric facilities was negligible, exclusion of the construction and decommissioning stages of the lifecycle resulted in the omission of 100% of the total emissions associated with the production of energy by hydroelectric facilities.

6.0 CONCLUSIONS

The phasing-out of coal-fired electricity generation, the increased capacity of renewable resources, and the ongoing contribution of nuclear as Ontario's base load supplier of electricity has resulted in a steady decline in GHG emissions from the electricity sector in Ontario since 2008. Currently, Ontario's energy demands are met through a mix of renewable and non-renewable resources, with nuclear representing approximately 60% of production. These declines are expected to be followed by an increase in emissions associated with a growing Ontario population, a recovering economy, and a reduction in energy production from nuclear units during a period of refurbishment resulting in an increased reliance on natural gas-fired plants (MOECC, 2013).

The loss of nuclear capacity with the scheduled closure of the Pickering Station after 2024 is anticipated to result in a significant increase in annual GHG emissions to the Ontario environment even under an optimal scenario in which renewable resources such as wind, solar and hydro increase their contribution to meet energy demand beyond the forecasted increase in production rather than shifting greater dependency on natural gas facilities. Additional losses in nuclear capacity would occur without refurbishment of existing nuclear facilities such as the Darlington Station, resulting in even greater increases in annual GHG emissions.

Given that nuclear represents a large source of energy production in Ontario and the operational stage produces a low rate of GHG emissions, the loss of energy-generating capacity due to the closure of nuclear facilities would result in a significant increase in annual GHG emissions in order for Ontario to meet its future energy requirements.

7.0 REFERENCES

- Amor, M.B., Pineau, P-O., Gaudreault, C., and Samson, R. 2011. Electricity trade and GHG emissions: Assessment of Quebec's hydropower in the northeastern American market (2006-2008). *Energy Policy* 39(2011): 1711-1721.
- Andseta, S., Thompson, M.J., Jarrell, J.P., Pendergast, D.R., 1998. CANDU reactors and greenhouse gas emissions. In: Proceedings of the 19th Annual Conference, Canadian Nuclear Society, Toronto, Ontario, Canada, October 18–21, 1998.
- Arvesen, A. and Hertwich, E.G. 2012. Assessing the life cycle environmental impacts of wind power: A review of present knowledge and research needs. *Renewable and Sustainable Energy Reviews*, 16(8): 5994-6006.
- Asthma Society of Canada and Bruce Power. 2014. Clean Air Ontario: Recognizing Nuclear's Role in Supporting Coal Phase-Out to Achieve Long-term Climate Change Goals. November, 2014.
- Bruce Power. 2015. 2014 Environmental Monitoring Program Report. B-REP-07000-00007. April 29, 2015.
- CERI. 2008. Comparative Life Cycle Assessment (LCA) of Base Load Electricity Generation in Ontario. Prepared for the Canadian Nuclear Association. Canadian Energy Research Institute. October, 2008.
- Chen, G.Q., Yang, Q., and Zhao, Y.H. 2011. Renewability of wind power in China: A case study of nonrenewable energy cost and greenhouse gas emission by a plant in Guangxi. *Renewable and Sustainable Energy Reviews*, 15(5): 2322-2329. Cited in: Nugent and Sovacool (2014).
- Crawford, R.H. 2009. Life cycle energy and greenhouse emissions analysis of wind turbines and the effect of size on energy yield. *Renewable and Sustainable Energy Reviews*, 13(9): 2653-2660.
- Davidsson. S., Hook, M., Wall, G. 2012. A review of life cycle assessments on wind energy systems. *The International Journal of Life Cycle Assessment*, 17(6): 729-742.
- Environment Canada. 2012. Assessment of the Environmental Performance of Solar Photovoltaic Technologies. A report funded under the Clean Energy Fund. Environment Canada, in partnership with Natural Resources Canada's CamnetENERGY. ISB N 978-1-100-21269-2. https://www.ec.gc.ca/scitech/B53B14DE-034C-457B-8B2B-39AFCFED04E6/ForContractor_721_Solar_Photovoltaic_Technology_e_09%20FINAL-update%202-s.pdf
- Fthenakis, V.M. and Kim, H.C. 2007. Greenhouse-gas emissions from solar electric- and nuclear power: A life-cycle study. *Energy Policy* 35(4): 2549-2557.
- Gagnon, L., and van de Vate, J.F. 1997. Greenhouse gas emissions from hydropower. *Energy Policy* 25(1):7–13

- GE Energy. 2006. Ontario Wind Integration Study. Final Report to: Ontario Power Authority (OPA), independent Electricity System Operator (IESO), Canadian Wind Energy Association (CanWEA). Prepared by GE Energy.
- Hatch. 2014. Lifecycle Assessment Literature Review of Nuclear, Wind and Natural Gas Power Generation. Prepared for the Canadian Nuclear Association. Hatch Ltd. October 9, 2014.
- Hondo, H. 2005. Life cycle GHG emission analysis of power generation systems: Japanese case. *Energy*, 30(2005): 2042-2056.
- Hsu, D.D., O'Donoghue, P., Fthenakis, V., Heath, G.A., Kim, H.C., Sawyer, P., Choi, J. and Turney, D. 2012. Life Cycle Greenhouse Gas Emissions of Crystalline Silicon Photovoltaic Electricity Generation. *Journal of Industrial Ecology*, 16(s1): S122-S135.
- Hydro Quebec. 2016. Greenhouse gas emissions and reservoirs. Accessed August 2016: <http://www.hydroquebec.com/sustainable-development/documentation-center/ghg-reservoir.html>
- IESO. 2015. LTEP (Long-Term Energy Plan): Comparison of 2014 Forecast vs. 2014 Actual Results. Independent Electricity System Operator. December 2015. <http://www.ieso.ca/Documents/LTEP/2014-Actual-vs-2014-Forecast-in-LTEP.pdf>
- IESO. 2016a. Supply Overview. Independent Electricity System Operator. <http://www.ieso.ca/Pages/Power-Data/Supply.aspx>
- IESO. 2016b. Wind Contracts. Independent Electricity System Operator. <http://www.powerauthority.on.ca/current-electricity-contracts/wind>
- IESO. 2016c. Natural Gas – Simple/Combined Cycle Contracts. Independent Electricity System Operator. <http://www.powerauthority.on.ca/current-electricity-contracts/sc-cc>
- IESO. 2016d. Solar Photovoltaic (PV) - Contracts. Independent Electricity System Operator. <http://www.powerauthority.on.ca/current-electricity-contracts/solar>
- Jungbluth, N., Bauer, C., Dones, R., and Frischknecht, R. 2005. Life Cycle Assessment for Emerging Technologies: Case Studies for Photovoltaic and Wind Power. *The International Journal of Life Cycle Assessment*, 10(1): 24-34.
- Lenzen, M. 2008. Life cycle energy and greenhouse gas emissions of nuclear energy: A review. *Energy Conversion and Management* 49 (2008): 2178-2199.
- Mallia, E., and Lewis, G. 2013. Life cycle greenhouse gas emissions of electricity generation in the province of Ontario, Canada. *Int J Life Cycle Assess* (2013) 18: 377-391.
- Martinez, E., Sanz, F., Pellegrini, S., Jimé, E., and Blanco, J. 2009. Life-cycle assessment of a 2-MW rated power wind turbine: CML method. *The International Journal of Life Cycle Assessment*, 14(1): 52-63. Cited in: Nugent and Sovacool (2014).
- MOE, 2013. Achieving Balance. Ontario's Long-Term Energy Plan. Ontario Ministry of Energy. http://www.energy.gov.on.ca/en/files/2014/10/LTEP_2013_English_WEB.pdf

- MOECC. 2013. Greenhouse Gas Emissions Reductions in Ontario. A Discussion Paper. Ontario Ministry of the Environment and Climate Change (formerly the Ministry of the Environment). January 2013.
- MOECC. 2016. Ontario's Five Year Climate Change Action Plan 2016-2020. Ministry of Environment and Climate Change.
http://www.applications.ene.gov.on.ca/ccap/products/CCAP_ENGLISH.pdf
- Noori, M., Kucukvar, M. and Tatari, O. 2015. Economic Input–Output Based Sustainability Analysis of Onshore and Offshore Wind Energy Systems. *International Journal of Green Energy*, 12(9): 939-948.
- Nugent, D. and Sovacool, B.K. 2014. Assessing the lifecycle greenhouse gas emissions from solar PV and wind energy: A critical meta-survey. *Energy Policy*, 65 (Feb 2014): 229-244.
- Oebels, K.B., Pacca, S. 2013. Life cycle assessment of an onshore wind farm located at the northeastern coast of Brazil. 53, 60-70. Cited in: Nugent and Sovacool (2014).
- OPA. 2014. Generation and Conservation Tabulations and Supply/Demand Balance. 2013 LTEP: Module 3. Ontario Power Authority. January 2014.
<http://powerauthority.on.ca/sites/default/files/planning/LTEP-2013-Module-3-Supply-Demand-Balance.pdf>
- Pacca, S. 2007. Impacts from decommissioning of hydroelectric dams: a life cycle perspective. *Clim. Chang* 84:281–294.
- Raadal, H.L., Gagnon, L., Modahl, I.S. and Hanssen, O.J. 2011. Life cycle greenhouse gas (GHG) emissions from the generation of wind and hydro power. *Renewable and Sustainable Energy Reviews*, 15(7): 3417-3422.
- Sovacool, B. K. 2008. Valuing the greenhouse gas emissions from nuclear power: A critical survey. *Energy Policy* 36(8): 2950–2963.
- Steinhurst, W., Knight, P., and Schultz, M. 2012. Hydropower Greenhouse Gas Emissions. State of the Research. Synapse Energy Economics, Inc. February 14, 2012.
<http://www.clf.org/wp-content/uploads/2012/02/Hydropower-GHG-Emissions-Feb.-14-2012.pdf>
- Thomson, R.C. and Harrison, G.P. 2015. Life cycle costs and carbon emissions of wind power.
http://www.climateexchange.org.uk/files/4014/3324/3180/Executive_Summary_-_Life_Cycle_Costs_and_Carbon_Emissions_of_Wind_Power.pdf
- Turney, D. and Fthenakis, V. 2011. Environmental impacts from the installation and operation of large-scale solar power plants. *Renewable and Sustainable Energy Reviews*, 15(6): 3261-3270.
- UNEP. 2010. The Main Greenhouse Gases. United Nations Environmental Programme
<http://www.grida.no/publications/vg/climate/page/3060.aspx>.

U.S. EPA. 2016. GHG Equivalencies Calculator – Calculations and references. U.S. Environmental Protection Agency. <https://www.epa.gov/energy/ghg-equivalencies-calculator-calculations-and-references>

Warner, E.S., and Heath, G.A. 2012. Life Cycle Greenhouse Gas Emissions of Nuclear Electricity Generation. *Journal of Industrial Ecology* 16 (S1): S73-S92.

Weisser, D. 2007. A guide to life-cycle greenhouse gas (GHG) emissions from electric supply techs., *Energy*, 32(9), 1543-1559.

APPENDIX A

LITERATURE SEARCH STRATEGY

(This page intentionally left blank)

APPENDIX A: LITERATURE SEARCH STRATEGY

A-1.0 INTRODUCTION

A systematic and comprehensive search of the published literature was conducted to identify, as best possible, all white (peer-reviewed published literature) and grey literature (literature available elsewhere) related to GHG emissions associated with power generation operations in the Ontario context. The literature search was performed in a step-wise manner using three search strategies:

- On-line electronic databases
- Citation sourcing
- Professional experience

A-1.1 On-Line Electronic Databases

A staged search strategy was employed, with the first stage of the search focused on identifying all white (peer-reviewed and published) literature related to GHG emissions from power generation in the Ontario context, the second stage aimed at identifying all grey literature (literature available elsewhere), and the third stage of the search intended to retrieve the primary or original publications and sources that served as the basis of the white and grey literature identified through the initial stages of the electronic search.

The first stage began with the development of a series of search strings representing various combinations of ‘primary’, ‘secondary’, and ‘tertiary’ search terms. The intent of the ‘primary’ search term was to identify literature specific to one of the power generation technologies of interest. The ‘secondary’ search term was intended to identify literature that reported GHG emissions in the context of power generation. The ‘tertiary’ search term was aimed at focusing the search on the literature specific to the Ontario context. In order to avoid possible bias in the selection of the search terms, two members of the study team were involved in the final choice of terms.

The ‘primary’ search terms selected for each power generation technology considered as part of the literature search are presented in Table A-1.

Power Generation Technology	Selected Search Terms
Nuclear	nuclear
Hydroelectric	hydroelectric hydropower
Onshore Wind	onshore wind
Solar	solar photovoltaic PV
Natural Gas	natural gas

The ‘secondary’ search terms selected to identify literature that reported GHG emissions in the context of power generation are presented in Table A-2. These terms were considered general and applicable to all power generation technologies.

Table A-2 ‘Secondary’ Search Terms	
<i>Selected Search Terms</i>	
	greenhouse emission carbon dioxide equivalent carbon dioxide electricity generation life cycle life-cycle LCA power generation

As the principal aim of the literature search was to identify GHG emissions specific to Ontario, the term “Ontario” was included as a ‘tertiary’ search term. At the same time, it was recognized that in order to accommodate the potential absence of Ontario-specific power generation-related GHG emissions data the search must necessarily extend beyond the Ontario borders. As a result, neighbouring jurisdictions were also considered with the understanding that because of the proximity or similarity to Ontario, the characteristics of the power generation technologies used and governing regulations would be similar. Table A-3 presents the ‘tertiary’ search terms.

Table A-3 ‘Tertiary’ Search Terms	
Location of Interest	Selected Search Terms
Ontario	Ontario
Relevant nearby jurisdictions	Canada United States

Using the primary, secondary, and tertiary search terms presented above, search strings were developed and used for the literature review (Table A-4).

Table A-4 Search Strings Utilized in the Literature Search	
Power Source Category	Search String
Nuclear	(nuclear) AND ((Ontario OR Canada OR "United States" OR USA OR U.S.)) AND ((greenhouse AND emission*)) AND (("carbon dioxide equivalent" OR "carbon dioxide" OR "electricity generation" OR "life cycle" OR "life-cycle" OR LCA OR "power generation"))
Hydroelectric	(hydroelectric OR hydropower) AND ((Ontario OR Canada OR "United States" OR USA OR U.S.)) AND ((greenhouse AND emission*)) AND (("carbon dioxide equivalent" OR "carbon dioxide" OR "electricity generation" OR "life cycle" OR "life-cycle" OR LCA OR "power generation"))
Onshore Wind	(onshore wind) AND ((Ontario OR Canada OR "United States" OR USA OR U.S.)) AND ((greenhouse AND emission*)) AND (("carbon dioxide equivalent" OR "carbon dioxide" OR "electricity generation" OR "life cycle" OR "life-cycle" OR LCA OR "power generation"))
Solar	(solar OR photovoltaic OR PV) AND ((Ontario OR Canada OR "United States" OR USA OR U.S.)) AND ((greenhouse AND emission*)) AND (("carbon dioxide equivalent" OR "carbon dioxide" OR "electricity generation" OR "life cycle" OR "life-cycle" OR LCA OR "power generation"))
Natural Gas	(natural gas) AND ((Ontario OR Canada OR "United States" OR USA OR U.S.)) AND ((greenhouse AND emission*)) AND (("carbon dioxide equivalent" OR "carbon dioxide" OR "electricity generation" OR "life cycle" OR "life-cycle" OR LCA OR "power generation"))

Using the search parameter approach described above, resources were further screened to determine relevance. Resources included for review were required to meet the following additional criteria:

- Resources from 2006 and onwards were deemed to be current; however, older documents were considered when necessary; and,
- English language.

This stage of the electronic literature search was performed with assistance from Documents Delivered Inc., a privately-owned document and retrieval service provider with access to numerous electronic databases.