

Western Waste Management Facility CNSC Reportable Events (Q1 2018)

Date of Occurrence	Report Number	Event Title
None		

Pickering Waste Management Facility CNSC Reportable Events (Q1 2018)

Date of Occurrence	Report Number	Event Title
None		

Darlington Waste Management Facility CNSC Reportable Events (Q1 2018)

Date of Occurrence	Report Number	Event Title
January 8, 2018	N-2018-00465	IAEA seal on tooling cabinet found by IAEA inspector to be broken.
January 17, 2018	N-2018-01297	Failure to notify IAEA of interruption of class IV power to IAEA equipment.

Western Waste Management Facility CNSC Reportable Events (Q2 2018)

Date of Occurrence	Report Number	Event Title
June 1, 2018	N-2018-12912	Low CO <sub>2</sub> Tank Level in Low Level Storage Building 11 – 14 Fire Suppression System.

Pickering Waste Management Facility CNSC Reportable Events (Q2 2018)

Date of Occurrence	Report Number	Event Title
None		

Darlington Waste Management Facility CNSC Reportable Events (Q2 2018)

Date of Occurrence	Report Number	Event Title
None		

## Western Waste Management Facility CNSC Reportable Events (Q3 2018)

Date of Occurrence	Report Number	Event Title
None		

## Pickering Waste Management Facility CNSC Reportable Events (Q3 2018)

Date of Occurrence	Report Number	Event Title
August 5, 2018	N-2018-17362	Booster panel circuit board not functioning properly causing fire detection trouble alarm in Used Fuel Dry Storage Building #3.

## Darlington Waste Management Facility CNSC Reportable Events (Q3 2018)

Date of Occurrence	Report Number	Event Title
July 18, 2018	N-2018-15928	Temporary Class IV power loss due to animal in switchgear.

Western Waste Management Facility CNSC Reportable Events (Q4 2018)

Date of Occurrence	Report Number	Event Title
October 12, 2018	N-2018-21728	IAIA loss of remote monitoring communication with the Digital Multi-Channel Optical Surveillance (DMOS) modem
November 9, 2018	N-2018-24225	Incorrect Frequency for Fire-Related Preventative Maintenance on a Firewater Flow Switch (Annually instead of Semi-Annually)

Pickering Waste Management Facility CNSC Reportable Events (Q4 2018)

Date of Occurrence	Report Number	Event Title
October 23, 2018	N-2018-22402	PWMF not notified of planned fire water outage, resulting in loss of fire water to PWMF

Darlington Waste Management Facility CNSC Reportable Events (Q4 2018)

Date of Occurrence	Report Number	Event Title
None		