

Report Number	Event Title
---------------	-------------

**Quarter: 2019Q1**

P-2018-26330	System Unavailable: Level 2 Impairment of Negative Pressure Containment System
P-2019-00133	System Unavailable: System Does Not Meet Design Intent of Unit 4 Primary Heat Transport System
P-2019-00333	Automatic Box-Up: Unit 5 Boxed-up on High Activity During Annulus Gas Purge
P-2019-02066	Unplanned Change in Reactor Power: Unit 7 Manual Setback Due To Erratic Turbine Governor Valve Fluctuations
P-2019-02418	Apparent Missed Test: Pump Check Valve Test Missed without an Approved Deferral
P-2019-02720	System Unavailable: System Does Not Meet Design Intent of Unit 7 Emergency Water System
P-2019-04011	System Unavailable: System Does Not Meet Design Intent of Powerhouse Emergency Venting System on Units 5, 6 and 8
P-2019-04686	Matter of Regulatory Interest: Potential Unplanned Internal Uptake well below Regulatory Limits
P-2019-05380	System Unavailable: System Does Not Meet Design Intent of Unit 6 Auxiliary Boiler Feed System
P-2019-05614	System Unavailable: System Does Not Meet Design Intent of Unit 1 Emergency Low Pressure Service Water System

**Quarter: 2019Q2**

P-2019-02071	System Unavailable: Level 2 impairment of the ECI system for Units 1, 4 and 5 to 8
P-2019-06374	System Unavailable: Does Not Meet Design Intent of Steam Protection Door and H-Line Wall for Unit 8
P-2019-07236	Unplanned Change in Reactor Power: Unit 6 Setback Due to Boiler Pressure Increase
P-2019-07451	System Unavailable: Level 2 impairment of the ECI system for Units 1, 4 and 5 to 8
P-2019-08406	Technical Operability Evaluation Initiated on Valve Bonnet Studs
P-2019-08491	Apparent Licence Condition Non-compliance: Shift Advisor Technical Support Under Minimum Shift Complement
P-2019-09090	Unplanned Change of Reactor Power: Unit 1 Reactor Manually Tripped on Dual RCS Failure
P-2019-09237	System Unavailable: System Does Not Meet Design Intent of Unit 6 Primary Heat Transport System
P-2019-09701	Smoke Observed from the Downstream Piping of the Heat Transport Circulation Pump
P-2019-09828	System Unavailable: Does Not Meet Design Intent of Steam Protection Door and H-Line Wall for Unit 6

**Quarter: 2019Q3**

P-2018-07576	System Unavailable: System Does Not Meet Design Intent of 056 Class III Power
P-2019-10627	Pressure Boundary: Pump Discharge Pipe Fretting Resulting in Potential Wall Thickness below Code Allowable Limit
P-2019-10999	External Event: High Lake Levels and Prevailing Winds Caused Water to Surround (but not enter) the SMB.
P-2019-12324	Misuse of Equipment: Tampering with Public Address Speaker
P-2019-12796	Apparent Licence Condition Non-Compliance: Program Document Issued without CNSC Notification
P-2019-13588	External Event: Small Fire in 317' Elevation Custodial Office
P-2019-14054	System Unavailable: System Does Not Meet Design Intent of a Unit 1 Main Control Room Uninhabitable Credited Component
P-2019-14748	System Unavailable: System Does Not Meet Design Intent of Unit 056 Emergency Water System

**Quarter: 2019Q4**

P-2019-01227	System Unavailable: System Does Not Meet Design Intent of Unit 8 Emergency Low Pressure Service Water
P-2019-16196	Apparent Licence Condition Non-compliance: Emergency Response Maintainer Under Minimum Shift Complement
P-2019-16710	System Unavailable: System Does Not Meet Design Intent of a Unit 1 Main Control Room Uninhabitable Credited Component
P-2019-17892	Unplanned Change in Reactor Power: Unit 7 Manual Setback Due To Turbine Governor Valve Failed Closed
P-2019-20309	Matter of Regulatory Interest: Fish Entering Screen House
P-2019-20685	Apparent Exceedance of Environmental Action Limit
P-2019-20918	Apparent Missed Test: Unit 5 Fuel Transfer System Equipment Check Test Missed without an Approved Deferral