

**Report Number** **Event Title****Quarter: 2022Q1**

P-2021-19820	Matter of Regulatory Interest: Employee Tested Positive for COVID-19
P-2021-19951	Matter of Regulatory Interest: Employees Tested Positive for COVID-19
P-2021-20006	Unplanned Change in Reactor Power: Unit 7 Setback
P-2022-00517	Oil Sheen Observed and Resolved at the Pickering 058 Outfall
P-2022-00523	Oil Sheen Observed and Resolved at the Pickering 014 Outfall
P-2022-01485	Degradation: Impairment of Unit 5 Emergency Water System, No Operability Impact
P-2022-02096	Degradation: Impairment of Unit 012 Class III Power System, No Operability Impact
P-2022-02759	Cigarette Butt Can Small Fire in Designated Smoking Area - Safely Resolved
P-2022-02770	Screen House Pump Small Fire - Safely Resolved
P-2022-03062	Degradation: Impairment of Steam Protection Door and H-Line Wall for Unit 8, No Operability Impact

**Quarter: 2022Q2**

P-2022-04588	Automatic Box-Up: Unit 4 Boxed-Up on High Activity
P-2022-06216	Misuse of Equipment: Tampering with Fire Extinguisher
P-2022-07190	Suspect Counterfeit or Fraudulent: Potential Nonconforming Material
P-2022-08004	Degradation: Impairment of Unit 1 Back-up Instrument Air System, No Operability Impact
P-2022-08087	Degradation: Impairment of Unit 4 Back-up Instrument Air System, No Operability Impact

**Quarter: 2022Q3**

P-2022-10317	Licence Condition Non-compliance: Pickering 014 ANO Under Minimum Shift Complement
P-2022-10569	Research Findings: Impact of Ageing of Shutdown System Neutron Overpower Pt-clad Inconel In-Core Flux Detectors Not Fully Accounted For In Design And Safety Analyses, No Operability Impact
P-2022-11063	Unplanned Potential Uptake of Tritium Oxide for an Employee, Exceeding Action Level
P-2022-13352	Misuse of Equipment: Tampering with Public Address Speaker
P-2022-13598	Degradation: Impairment of Unit 5 Primary Heat Transport System, No Operability Impact
P-2022-13898	Degradation: Impairment of Unit 5 Emergency Low Pressure Service Water System, No Operability Impact
P-2022-13923	Degradation: Impairment of Unit 6 Primary Heat Transport System, No Operability Impact

**Quarter: 2022Q4**

P-2022-14676	Unplanned Change in Reactor Power: Unit 8 Power Increased as a result of ICFD Adjustment on controlling DCCX
P-2022-14790	Licence Condition Non-compliance: Emergency Response Maintainer Under Minimum Shift Complement
P-2022-15570	Degradation, Impairment of Unit 6 Primary Heat Transport System, No Operability Impact
P-2022-15843	Environmental Release of Vacuum Building Service Water
P-2022-16532	Degradation, Impairment of Unit 5 Emergency Water System, No Operability Impact
P-2022-16899	Matter of Regulatory Interest: Un-ionized Ammonia In Unit 014 Condenser Cooling Water Sample Exceeded ECA Limit
P-2022-16942	Degradation, Impairment of Negative Pressure Containment System on Unit 5, No Operability Impact
P-2022-17201	Unplanned Change in Reactor Power: Unit 4 Reactor Trip on Boiler Feedline Low Pressure
P-2022-17579	Degradation, Impairment of 078 Emergency Coolant Injection System, No Operability Impact
P-2022-17887	Unplanned Change in Reactor Power: Unit 4 Power Unexpectedly Raised By DCC1 During Maintenance Activities
P-2022-18035	Unplanned Change in Reactor Power: Unit 5 Reactor Setback following Turbine Trip
P-2022-19040	Missed Test: Unit 1 Emergency Low Pressure Service Water Pump Performance Test and Vacuum Building Vacuum Pump Trip Test, Now Complete
P-2022-19262	Degradation, Impairment of Unit 8 Powerhouse Environmental Protection System, No Operability Impact