

Report Number	Event Title
---------------	-------------

Quarter: 2024Q1

P-2023-19876	Degradation: Impairment of Unit 8 Emergency High Pressure Service Water, No Operability Impact
P-2023-20314	Unit 7 Reactor Setback on Bleed Condenser High Level
P-2024-00203	Degradation: Impairment of Unit 7 Primary Heat Transport System, No Operability Impact
P-2024-00365	Degradation: Impairment of Site Electrical System, No Operability Impact
P-2024-00994	Matter of Regulatory Interest: Unit 7 Fuel Channels K13E & B13E Found Unlocked
P-2024-01243	Unplanned Change in Reactor Power: Unit 8 Reactor Power Reduced During Transfer of Control From DCCY to DCCX
P-2024-01416	Degradation: Impairment of Unit 4 Primary Heat Transport System, No Operability Impact
P-2024-02208	Matter of Regulatory Interest: Employee fractured left ankle on a wet floor surface
P-2024-02303	Reactor Trip: Unit 8 Tripped Via Shutdown System 1
P-2024-02394	Hazmat Response Procedure Entered Due To Fire Retardant Fluid Leak. No Safety or Environmental Impact
P-2024-03268	Licence Non-Compliance: Primary Heat Transport Pump Motors sent to Vendor Without Export Licence
P-2024-04274	Missed Test: Unit 5 Airlock Relief Valve As-Found Test Missed without an Approved Deferral
P-2024-04621	Unplanned Change in Reactor Power: Unit 4 Setback As A Result Of Misposition

Quarter: 2024Q2

P-2024-06004	Minor Spill from Breathing Air Compressor, No Environmental Impact
P-2024-06170	West Fuelling Machine Irradiated Fuel Pushed Against Transfer Port Closure Plug
P-2024-06420	Matter of Regulatory Interest: Elevated Weekly Gross Beta Analysis Result for Unit 014 Reactor Building Service Water Effluent (Entrained Sediment Expected to be from Lake Ontario)
P-2024-06547	Licence Non-Compliance: Unlabelled Waste Bags
P-2024-07256	Matter of Regulatory Interest: Elevated Weekly Gross Beta Analysis Result for Unit 014 Reactor Building Service Water Effluent (Entrained Sediment Expected to be from Lake Ontario)
P-2024-08053	Open Flame Observed at Primary Heat Transport Hydrogen Addition Rupture Disc Vent, No Safety or Operability Impact
P-2024-08296	Unplanned Change in Reactor Power: Unit 4 Reactor Trip Due To a Protection Circuit Fault in the Hydro One Switchyard
P-2024-09067	Reactor Trip: Unit 5 Tripped Via Shutdown System 2
P-2024-10190	Matter of Regulatory Interest: Potential Unanticipated Neutron Radiation (No Recordable Neutron Dose Received)

Quarter: 2024Q3

P-2024-10198	Licence Non-Compliance: Visitor Left Unescorted in the Protected Area, Safely Resolved
P-2024-10272	Licence Non-Compliance: Container with Radioactive Nuclear Substance Not Labelled in Accordance with Radiation Protection Regulations
P-2024-10284	24 Hour Daily Average Effluent Temperature Exceeded the Environmental Compliance Approval Limit, No Environmental Impact
P-2024-10840	Degradation: Impairment of Unit 6 Emergency Water System, No Operability Impact
P-2024-11842	Missed Predefine: Preventive Maintenance Testing, Instrument Calibration and Replacement
P-2024-12296	Unplanned Change in Reactor Power: Unit 5 Shutdown Due To High Consumption Rate Of Hydrogen Of The Generator System
P-2024-12989	Potential Environmental Release of Fire Resistant Fluid, No Environmental Impact
P-2024-13507	Licence Non-Compliance: Missed Notification to CNSC staff on Unit 2 and Unit 3 Decommissioning Pilot Project
P-2024-13773	Degradation: Impairment of Unit 7 and Unit 8 Emergency Water System, No Operability Impact

Quarter: 2024Q4

P-2024-15486	Matter of Regulatory Interest: Data Radiation Monitors Overdue for Calibration, Safely Resolved
P-2024-17240	Licence Non-Compliance: Unit 1 Fuel Bundle Discrepancy, Safely Resolved
P-2024-19500	Licence Non-Compliance: Incomplete Written Notification to CNSC staff
P-2024-20102	Unplanned Change in Reactor Power: Unit 8 Reactor Power Derated Due to Digital Control Computer X Stall
P-2024-20149	Matter of Regulatory Interest: Pressure Tube Burst Test Result from Artificially Hydrided Burst Test Specimen, Deviation from Nominal Prediction, no Fitness for Service Concern